

# Australasian Standard Project

## Room Data Sheets

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 1110</b>
<b>Room Name</b>	<b>ADL Bathroom</b>	<b>Room Code: ADLB</b>
<b>Area</b>	12.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	12.0 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 patient; 1 - 2 staff	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>A bathroom for patient 'Activities of Daily Living' assessment and training. The ADL Bathroom provides for training of patients to use a domestic bath, patient dressing, undressing, grooming and handwashing. Facilities include a domestic bath installed in a corner of the room, accessible toilet and handbasin and a separate shower within the room. A low height adjustable shower is required over the bath.</p> <p>Additional Design Requirements:</p> <ul style="list-style-type: none"> <li>- The shower area must not have a raised hob.</li> <li>- The entrance to the bathroom is to be flush with the adjoining corridor.</li> </ul> <p>Acoustics: Sound attenuation level - Medium. Acoustic privacy required.</p> <p>Body Protected electrical area</p>	
<b>Amendment</b>	<p>24.01.05, - First Draft</p> <p>22.03.05, - BOB user review, doors, fittings modified</p>	

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening, privacy latch
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved		tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		tiles also acceptable
3000	Wall finish	Paint	Acrylic, washable			
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height		to shower area, tiles also acceptable
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		to bath & basin areas, tiles also acceptable

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
2300	Chair: shower	Furniture/ Fitting	3	2	1 in shower space
3400	Coathook	Metalwork	1	2	1 at 1000H
4700	Curtain track: privacy screen	Metalwork	1	1	to entry door

# Australasian Standard Project

## Room Data Sheets

Department **Standard Components**  
 Room Name **ADL Bathroom**

Room Tag: **1110**  
 Room Code: **ADLB**

ID	Description	Category	Group	Qty	Selection
4800	Curtain track: shower	Metalwork	1	1	
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to entry door
5300	Curtain: shower	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	near entry
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
8450	Grab rail: Shower	Metalwork	1	1	
8500	Grab rail: WC, hinged	Metalwork	1	2	drop down rail
13700	Mirror	Metalwork	1	1	above basin
13800	Mirror: full length	Metalwork	1	1	dressing
19800	Shelf: laminate	Furniture/ Fitting	1	1	150mmW x 400mmL
20650	Soap/ shampoo holder	Furniture/ Fitting	1	2	
23700	Towel rail	Metalwork	1	1	
23865	Transfer bench	Furniture/ Fitting	3	1	portable - not fixed, near bath

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3050	Basin: handwash, disabled	1	1	___	___	yes	___	yes	yes	yes	___	lever taps
3201	Bath: domestic	1	1	___	___	yes	___	yes	yes	yes	___	
47400	Shower: hand-held	1	1	___	___	yes	___	yes	yes	yes	___	low level over bath
47400	Shower: hand-held	1	1	___	___	yes	___	yes	yes	yes	___	Short lever taps
55650	Toilet suite: disabled use	1	1	___	___	yes	___	___	yes	yes	___	

### Services

ID	Description	Service Category	Qty	Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	2	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8000	Patient/ Staff call	Nurse Call	3	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	2	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	1	