

# Australasian Standard Project

## Room Data Sheets

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 1180</b>
<b>Room Name</b>	<b>After Hours Blood Fridge</b>	<b>Room Code: AHBBF</b>
<b>Area</b>	3.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	3.0 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 - 2 intermittently	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	The After Hours Blood Fridge is a discreet area for refrigerated storage of blood and blood products for after hours access by authorised personnel. The After Hours Blood Fridge may be located in close proximity to a Critical Care Unit.	
<b>Amendment</b>	14.03.05, - First Draft	

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		As required; Equal to 'Acrovyn'

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
1050	Bench: laminate	Furniture/ Fitting	1	1	for recording
17385	Pinboard/ whiteboard combination	Furniture/ Fitting	2	1	combination unit

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
21805	Freezer: blood products	3	1	yes	opt	—	—	—	—	—	—	with temperature alarm, optional
44300	Refrigerator: blood products	3	1	yes	opt	—	—	—	—	—	—	with temperature alarm

### Services

ID	Description	Service Category	Qty	Remarks
1085	Temperature monitor & alarm	Communications	2	1 to each blood fridge/ freezer
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9010	GPO: Emergency power, single	Power	2	1 to each blood fridge/ freezer