

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 1206</b>
<b>Room Name</b>	<b>Airlock - Entry, 6m2</b>	<b>Room Code: AIRLE-6</b>
<b>Net Room Area Briefed</b>	6.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Briefed Area</b>	6.00 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	N/A	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>Airlock associated with a Main Entry Area for wind/ weather protection and to maintain air pressurisation. It will be used by a wide range of people including fully ambulant, persons using a wide range of walking aids, persons in wheelchairs or on trolleys and the general public.</p> <p>The size of the air lock should allow for several people to enter before the second door opens and should reflect the level of service provision.</p> <p>Entry doors may be glazed and automatic. Walls may also be glazed. 'After-hours' access may require intercom or special security provisions.</p>	
<b>Amendment</b>	<p>24.03.05, - First Draft                  28.05.07, - Area revised                  15.12.08, - 2008 AUSHFG Review; description &amp; fabric modified, FE &amp; services added</p>	

**Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
9220	Doors	Alum/ Safety glass	Powdercoat/ paint	Double leaf, fully glazed		1600mm clear opening, may be automatic, lockable
1150	Floor finish	Composite	Slip resistant	Floor mat, recessed		Optional; Attention to detailing of recessed mat to avoid trip hazard
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Default = vinyl, or other suitable slip resistant floor finish
2015	Skirting					Skirting to suit built fabric
3000	Wall finish	Paint	Acrylic, washable			

**Fittings and Furniture (FF)**

**Fixtures, Equipment and associated Services (FE)**

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection / Remarks
7300	Camera: CCTV security	1	1	yes	___	___	___	___	___	___	___	optional

**Services**

ID	Description	Service Category	Qty	Selection / Remarks

**Department** | **Standard Components**  
**Room Name** | **Airlock - Entry, 6m2**

**Room Tag:** 1206  
**Room Code:** AIRLE-6

ID	Description	Service Category	Qty	Selection / Remarks
1035	Door buzzer	Communications	1	optional
1040	Intercom	Communications	1	optional
1100	TV: CCTV	Communications	1	optional
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9015	GPO: Cleaner	Power	1	
9060	GPO: Special: for equipment	Power	1	optional; for CCTV
10020	Card access	Security	1	optional; swipe card access