

AusHFG Standard Components Document Register

13/05/2019



SC= Standard Component RDS = Room Data Sheet RLS = Room Layout Sheet

No. of Standard Components = 251

Code	SC Name	RDS Revision	RDS Date	RLS Revision	RLS Date	Status	Changes since last AusHFG Standard Components Document Register issue
1BR-BA	1 Bed Room - Bariatric	1	05.04.2018	1	05.04.2018		
1BR-H-12	1 Bed Room - Holding, 12m2	3	22.06.2017	3	20.03.2017		
1BR-IC	1 Bed Room - Intensive Care	1	29.05.2019	1	29.05.2019	This Standard Component has been updated	General update following ERG review - replaces PBCE-25 Patient Bay - Critical (Enclosed) 25m2
1BR-IS-N1	1 Bed Room - Isolation - Negative Pressure, Type 1	4	05.04.2018	4	05.04.2018		
1BR-IS-N2	1 Bed Room - Isolation - Negative Pressure, Type 2	1	05.04.2018	1	05.04.2018		
1BR-MH-A	1 Bed Room - Mental Health - Inboard Ensuite, 15m2	5	02.07.2018	4	02.07.2018		
1BR-MH-C	1 Bed Room - Mental Health - Back to Back Ensuites, 15m2	5	02.07.2018	4	02.07.2018		
1BR-SP-A1	1 Bed Room - Special, Inboard Ensuite, Type 1	6	05.04.2018	4	05.04.2018		
1BR-SP-A2	1 Bed Room - Special, Inboard Ensuite, Type 2	1	05.04.2018	1	05.04.2018		
1BR-SP-B	1 Bed Room - CCU, 20m2	4	22.06.2017	3	20.03.2017		
1BR-ST-A1	1 Bed Room - Inboard Ensuite, Type 1	5	05.04.2018	5	05.04.2018		
1BR-ST-A2	1 Bed Room - Inboard Ensuite, Type 2	5	05.04.2018	3	05.04.2018		
1BR-ST-A3	1 Bed Room - Inboard Ensuite, Type 3	5	05.04.2018	3	05.04.2018		
1BR-ST-B1	1 Bed Room - Outboard Ensuite, Type 1	5	05.04.2018	5	05.04.2018		
1BR-ST-B2	1 Bed Room - Outboard Ensuite, Type 2	1	05.04.2018	1	05.04.2018		
1BR-ST-B3	1 Bed Room - Outboard Ensuite, Type 3	1	05.04.2018	1	05.04.2018		
1BR-ST-D	1 Bed Room - Back to Back Ensuite	1	05.04.2018	1	05.04.2018		
2BR-ST-A1	2 Bed Room - Inboard Ensuite, Type 1	5	05.04.2018	5	05.04.2018		
2BR-ST-A2	2 Bed Room - Inboard Ensuite, Type 2	1	05.04.2018	1	05.04.2018		
2BR-ST-B	2 Bed Room - Outboard Ensuite	5	05.04.2018	4	05.04.2018		
4BR-ST	4 Bed Room - Inboard Ensuite	5	05.04.2018	5	05.04.2018		
ADLB	ADL Bathroom	3	20.03.2017	3	20.03.2017		
ADLBR	ADL Bed Room	3	20.03.2017	3	20.03.2017		
ADLD	ADL Dining / Lounge	3	20.03.2017	3	20.03.2017		
ADLK-ENC	ADL Kitchen - Enclosed	3	20.03.2017	3	20.03.2017		
ADLK-OP	ADL Kitchen - Open Bay	3	20.03.2017	3	20.03.2017		
ADLL	ADL Laundry	3	20.03.2017	3	20.03.2017		
AHBBF	After Hours Blood Fridge	3	20.03.2017	4	20.03.2017		
AHDR	After Hours Drug Store	3	20.03.2017	3	20.03.2017		
AIRLE-12	Airlock - Entry, 12m2	2	20.03.2017	2	20.03.2017		
AIRLE-6	Airlock - Entry, 6m2	5	20.03.2017	4	20.03.2017		
ANAE-16	Anaesthetic Preparation Room, 16m ²	1	02.07.2018	1	02.07.2018		
ANCRT	Angiography Control/ Reporting Room	3	20.03.2017	3	20.03.2017		
ANPR	Angiography Procedure Room	3	20.03.2017	3	20.03.2017	This Standard Component is currently under review	
ANRM	Anteroom	4	20.03.2017	5	20.03.2017		
ANSS	Angiography Sterile Store/ Set-up	3	20.03.2017	3	20.03.2017	This Standard Component is currently under review	
ASPR-20	Assembly/ Preparation (Pharmacy), 20m2	3	20.03.2017	3	20.03.2017		
ASPR-30	Assembly/ Preparation (Pharmacy), 30m2	3	20.03.2017	3	20.03.2017		
AUDIO	Audiology Testing Room	3	20.03.2017	3	20.03.2017		
BATH	Bathroom	4	20.03.2017	5	20.03.2017		
BATM-2	Bay - ATM, 2m2	3	20.03.2017	5	20.03.2017		
BBEV-ENC	Bay - Beverage, Enclosed, 5m2	4	20.03.2017	4	10.12.2008		
BBEV-OP	Bay - Beverage, Open Plan, 4m2	5	20.03.2017	6	20.03.2017		
BBW	Bay - Blanket/ Fluid Warmer	3	20.03.2017	3	20.03.2017		
BES	Bay - Emergency Shower	3	20.03.2017	2	20.03.2017		
BFLW-ENC	Bay - Flowers, Enclosed, 4m2	5	20.03.2017	6	20.03.2017		
BFLW-OP	Bay - Flowers, Open Plan, 2m2	5	20.03.2017	6	20.03.2017		
BHW	Bay - Height/ Weight	3	20.03.2017	2	20.03.2017		
BHWS-A	Bay - Handwashing, Type A	5	20.03.2017	6	20.03.2017		
BHWS-B	Bay - Handwashing, Type B	5	20.03.2017	5	20.03.2017		
BHWS-C	Bay - Handwashing, Type C	5	20.03.2017	4	20.03.2017		
BHWS-PPE	Bay - Handwashing/ PPE	5	20.03.2017	3	20.03.2017		
BIRM-A	Birthing Room - LDR Without Bath	4	05.04.2018	4	05.04.2018		
BIRM-B	Birthing Room - LDR With Bath	1	05.04.2018	1	05.04.2018		
BLIN	Bay - Linen	5	20.03.2017	5	20.03.2017		
BLST	Blood Store	3	20.03.2017	3	20.03.2017		
BMEQ-4	Bay - Mobile Equipment, 4m2	5	20.03.2017	5	20.03.2017		
BMEQ-6	Bay - Mobile Equipment, 6m2	5	20.03.2017	5	20.03.2017		

AusHFG Standard Components Document Register

13/05/2019



SC= Standard Component RDS = Room Data Sheet RLS = Room Layout Sheet

No. of Standard Components = 251

Code	SC Name	RDS Revision	RDS Date	RLS Revision	RLS Date	Status	Changes since last AusHFG Standard Components Document Register issue
BMT-4	Bay - Meal Trolley, 4m2	5	20.03.2017	5	20.03.2017		
BPATH	Bay - Pathology	3	20.03.2017	2	20.03.2017		
BPH	Bay - Public Telephone	5	20.03.2017	5	20.03.2017		
BPPE	Bay - PPE (Personal Protective Equipment)	5	20.03.2017	6	20.03.2017		
BPTS	Bay - Pneumatic Tube	3	20.03.2017	2	20.03.2017		
BRES	Bay - Resuscitation Trolley	5	20.03.2017	6	20.03.2017		
BS-1	Bay - Storage, 1m2	5	20.03.2017	4	20.03.2017		
BS-4	Bay - Storage, 4m2	5	20.03.2017	4	20.03.2017		
BSE-1	Bay - Storage (Enclosed), 1m2	5	20.03.2017	4	20.03.2017		
BUT-1	Bay - Utility, 1m2	5	20.03.2017	4	20.03.2017		
BUT-2	Bay - Utility, 2m2	5	20.03.2017	4	20.03.2017		
BVM-3	Bay - Vending Machine	5	20.03.2017	5	20.03.2017		
BWC	Bay - Wheelchair Park	5	20.03.2017	4	20.03.2017		
BWD-1	Bay - Water Dispenser	3	20.03.2017	2	20.03.2017		
CHPT	Change Cubicle - Patient, 2m2	5	20.03.2017	5	20.03.2017		
CHPT-12	Change Room - Patient (Male/Female), 12m2	3	20.03.2017	2	20.03.2017		
CHPT-D	Change Cubicle - Accessible, 4m2	5	20.03.2017	5	20.03.2017		
CHST-10	Change - Staff (Male/Female), 10m2	5	20.03.2017	4	20.03.2017		
CHST-20	Change - Staff (Male/Female), 20m2	3	20.03.2017	2	20.03.2017		
CHST-35	Change - Staff (Male/Female), 35m2	5	20.03.2017	5	20.03.2017		
CLAB	Catheter Laboratory Procedure Room	3	20.03.2017	3	20.03.2017	This Standard Component is currently under review	
CLCRT	Catheter Lab Control/ Reporting Room	3	20.03.2017	3	20.03.2017	This Standard Component is currently under review	
CLRM-10	Cleaner's Room, 10m2	5	20.03.2017	3	20.03.2017		
CLRM-5	Cleaner's Room, 5m2	3	20.03.2017	5	20.03.2017		
CLUP-10	Clean-Up Room - Shared, 10m2	1	02.07.2018	1	02.07.2018		
CLUP-7	Clean-Up Room, 7m2	4	20.03.2017	5	20.03.2017		
CLUP-P	Clean-Up Room (Pathology), 12m2	3	20.03.2017	3	20.03.2017		
CLUR-12	Clean Utility/ Medication Room, 12m2	5	20.03.2017	4	20.03.2017		
CLUR-14	Clean Utility/ Medication Room, 14m2	5	20.03.2017	6	20.03.2017		
CLUR-8	Clean Utility/ Medication Room - Sub, 8m2	5	20.03.2017	5	20.03.2017		
COMM	Communications Room	5	20.03.2017	4	20.03.2017		
CONS	Consult Room	5	20.03.2017	7	20.03.2017		
CONS-ENT-OP	Consult Room - ENT/ Ophthalmology	6	29.05.2019	7	29.05.2019	This Standard Component has been updated	General update following ERG review
CONS-UN	Consult Room - Universal Access	1	05.04.2018	1	05.04.2018		
CORR	Corridor - Patient Treatment Areas	4	22.06.2017	2	20.03.2017		
CTCR	CT Imaging Control Room	4	29.05.2019	4	29.05.2019	This Standard Component has been updated	General update following ERG review - replaces CTCR CT Scanning - Control Room
CTIR	CT Imaging Room	1	29.05.2019	1	29.05.2019	This Standard Component has been updated	General update following ERG review - replaces CTPR CT Scanning - Procedure Room
DENSR-14	Dental Surgery, 14m2	3	20.03.2017	4	20.03.2017		
DENSR-16	Dental Surgery, 16m2	3	20.03.2017	3	20.03.2017		
DENW	Dental Workroom	3	20.03.2017	3	20.03.2017		
DINBEV-25	Dining Room/Beverage Bay (Mental Health), 25m2	3	20.03.2017	4	20.03.2017		
DINR	Dining - Patients	3	20.03.2017	2	20.03.2017		
DISP-10	Disposal Room, 10m2	5	20.03.2017	3	20.03.2017		
DISP-8	Disposal Room, 8m2	5	20.03.2017	4	20.03.2017		
DTUR-10	Dirty Utility, 10m2	5	20.03.2017	4	20.03.2017		
DTUR-12	Dirty Utility, 12m2	5	20.03.2017	5	20.03.2017		
DTUR-14	Dirty Utility, 14m2	5	20.03.2017	4	20.03.2017		
DTUR-5	Dirty Utility - Sub, 8m2	5	20.03.2017	4	20.03.2017		
ECHO	Echocardiography - Trans-oesophageal	3	20.03.2017	4	20.03.2017		
ECL-10	Equipment Clean-Up, 10m2	5	20.03.2017	4	20.03.2017		
ECL-12	Equipment Clean-Up/Loan Equipment, 12m2	5	20.03.2017	2	20.03.2017		
ECL-14	Equipment Clean-Up, 14m2	5	20.03.2017	4	20.03.2017		
ECL-8	Equipment Clean-Up, 8m2	5	20.03.2017	4	20.03.2017		
ENPR	Procedure Room - Endoscopy	1	02.07.2018	1	02.07.2018		
ENS-ACC	Ensuite - Accessible, 7m2	2	20.03.2017	4	20.03.2017		
ENS-BA	Ensuite - Bariatric, 7m2	2	20.03.2017	2	20.03.2017		
ENS-BR	Ensuite - Birthing, 7m2	1	05.04.2018	1	05.04.2018		
ENS-MH-A	Ensuite - Mental Health, Inboard, 5m2	4	02.07.2018	4	02.07.2018		

AusHFG Standard Components Document Register

13/05/2019



SC= Standard Component RDS = Room Data Sheet RLS = Room Layout Sheet

No. of Standard Components = 251

Code	SC Name	RDS Revision	RDS Date	RLS Revision	RLS Date	Status	Changes since last AusHFG Standard Components Document Register issue
ENS-MH-B	Ensuite - Mental Health, Inboard Access from Corridor, 5m2	3	02.07.2018	2	02.07.2018		
ENS-SH	Ensuite - Shared, 6m2	4	20.03.2017	5	20.03.2017		
ENS-SP	Ensuite - Special, 6m2	4	20.03.2017	5	20.03.2017		
ENS-ST-A1	Ensuite - Inboard - Alternative 1, 5m2	4	20.03.2017	6	20.03.2017		
ENS-ST-A2	Ensuite - Inboard - Alternative 2, 5m2	4	20.03.2017	2	18.04.2006		
ENS-ST-A3	Ensuite - Inboard - Alternative 3, 5m2	4	20.03.2017	1	03.08.2005		
ENS-ST-B	Ensuite - Outboard, 5m2	4	20.03.2017	4	19.05.2005		
ENS-ST-C	Ensuite - Back to Back, 5m2	1	05.04.2018	1	05.04.2018		
FLUO	Fluoroscopy Room	1	29.05.2019	1	29.05.2019	This Standard Component has been updated	General update following ERG review - replaces SCRNG Screening Room (Fluoroscopy)
FLUOC	Fluoroscopy Control Room	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
GENXR	General X-Ray Room	4	29.05.2019	4	29.05.2019	This Standard Component has been updated	General update following ERG review
GRE	Goods Receipt - Pharmacy	3	20.03.2017	3	20.03.2017		
GYAH-45	Gymnasium, 45m2	3	20.03.2017	3	20.03.2017		
GYAH-60	Gymnasium, 60m2	4	20.03.2017	3	20.03.2017		
HYDP	Hydrotherapy Pool	4	20.03.2017	5	20.03.2017		
INTF	Interview Room	4	20.03.2017	5	20.03.2017		
INTF-MH	Interview Room - Mental Health	1	02.07.2018	1	02.07.2018		
LAUN-MH	Laundry - Mental Health, 6m2	4	20.03.2017	4	20.03.2017		
LAUN-PT	Laundry - Patient, 6m2	5	20.03.2017	4	20.03.2017		
LNPA-12	Lounge - Parent, 12m2	5	20.03.2017	4	20.03.2017		
LNPF-20	Lounge - Patient / Family, 20m2	2	20.03.2017	2	20.03.2017		
LNPT-10	Lounge - Patient/ Family, 10m2	5	20.03.2017	5	20.03.2017		
LNPT-30	Lounge - Patient/ Family, 30m2	5	20.03.2017	5	20.03.2017		
MAMMO	Mammography Room	4	29.05.2019	4	29.05.2019	This Standard Component has been updated	General update following ERG review
MEET-12	Meeting Room, 12m2	5	20.03.2017	4	20.03.2017		
MEET-9	Meeting Room, 9m2	5	20.03.2017	5	20.03.2017		
MEET-L-15	Meeting Room, 15m2	5	20.03.2017	4	20.03.2017		
MEET-L-20	Meeting Room, 20m2	5	20.03.2017	6	20.03.2017		
MEET-L-30	Meeting Room, 30m2	5	20.03.2017	6	20.03.2017		
MEET-L-55	Meeting Room, 55m2	2	20.03.2017	2	20.03.2017		
MOR-AU	Mortuary - Autopsy Room	3	20.03.2017	3	20.03.2017		
MOR-CS	Mortuary - Cool Store	3	20.03.2017	3	20.03.2017		
MOR-CU	Mortuary - Clean-up Area	3	20.03.2017	3	20.03.2017		
MOR-EX	Mortuary - Exit	3	20.03.2017	3	20.03.2017		
MOR-VR	Mortuary - Viewing Room	4	20.03.2017	3	20.03.2017		
MOR-W	Mortuary - Waiting	4	20.03.2017	3	20.03.2017		
MRICR	MRI Control Room	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
MRIR	MRI Room	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
NBGC	Neonatal Bay - General Care, 5m2	3	20.03.2017	3	20.03.2017	This Standard Component is currently under review	
NBICU	Neonatal Bay - Intensive Care, 12m2	3	20.03.2017	3	20.03.2017	This Standard Component is currently under review	
NBSC	Neonatal Bay - Special Care, 10m2	3	20.03.2017	3	20.03.2017	This Standard Component is currently under review	
OFF-2P	Office - 2 Person Shared, 12m2	5	20.03.2017	6	20.03.2017		
OFF-3P	Office - 3 Person Shared, 15m2	5	20.03.2017	6	20.03.2017		
OFF-4P	Office - 4 Person Shared, 20m2	5	20.03.2017	6	20.03.2017		
OFF-CLN	Office - Clinical Workroom	5	20.03.2017	5	20.03.2017		
OFF-S12	Office - Single Person, 12m2	5	20.03.2017	4	20.03.2017		
OFF-S9	Office - Single Person, 9m2	5	20.03.2017	6	20.03.2017		
OFF-SWS	Office - Shared Workstation, 2.2m2	2	20.03.2017	2	20.03.2017		
OFF-WI-5	Office - Write-up, 5m2	2	20.03.2017	2	20.03.2017		
OPG	OPG Room	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
ORGN	Operating Room - General	5	02.07.2018	6	02.07.2018		
OVBR	Overnight Stay - Bedroom	5	20.03.2017	4	20.03.2017		
OVES	Overnight Stay - Ensuite	5	20.03.2017	4	20.03.2017		
PAR	Parenting Room	4	20.03.2017	3	20.03.2017		
PBAT	Patient Bay, Emergency - Ambulance Triage	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
PBIC	Patient Bay - Intensive Care	1	29.05.2019	1	29.05.2019	This Standard Component has been updated	General update following ERG review - replaces PBC-24 Patient Bay - Critical, 24m2
PBTR-A	Patient Bay, Emergency - Acute Treatment	5	29.05.2019	6	29.05.2019	This Standard Component has been updated	General update following ERG review
PBTR-AS	Patient Room, Emergency - Acute Treatment Special	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue

AusHFG Standard Components Document Register

13/05/2019



SC= Standard Component RDS = Room Data Sheet RLS = Room Layout Sheet

No. of Standard Components = 251

Code	SC Name	RDS Revision	RDS Date	RLS Revision	RLS Date	Status	Changes since last AusHFG Standard Components Document Register issue
PBTR-FT	Patient Bay, Emergency - Fast Track	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
PBTR-H-6	Patient Bay - Holding, 6m2	5	20.03.2017	5	20.03.2017		
PBTR-H-9	Patient Bay - Holding, 9m2	5	20.03.2017	6	20.03.2017		
PBTR-NA	Patient Bay, Emergency - Non Acute Treatment	5	29.05.2019	5	29.05.2019	This Standard Component has been updated	General update following ERG review
PBTR-R	Patient Bay, Emergency - Resuscitation	5	29.05.2019	6	29.05.2019	This Standard Component has been updated	General update following ERG review
PBTR-RS1	Patient Bay - Recovery, Stage 1, 9m2	4	02.07.2018	4	02.07.2018		
PET-CT	PET-CT Imaging Room	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
PHA-CO	Pharmacy Counter	3	20.03.2017	3	20.03.2017		
PLAP-10	Play Area - Paediatric, 10m2	5	20.03.2017	5	20.03.2017		
PLAP-20	Play Area - Paediatric, 20m2	5	20.03.2017	4	20.03.2017		
PLST	Plaster Room	4	20.03.2017	4	20.03.2017		
PODTR-12	Podiatry Treatment, 12m2	5	20.03.2017	5	20.03.2017		
PODTR-14	Podiatry Treatment, 14m2	5	20.03.2017	4	20.03.2017		
PREP	Preparation Room - Non Sterile (Pharmacy)	3	20.03.2017	3	20.03.2017		
PROC-16	Procedure Room, 16m2	4	20.03.2017	2	10.03.2009		
PROC-20	Procedure Room, 20m2	5	20.03.2017	5	20.03.2017		
PROP-2	Property Bay - Staff, 2m2	5	20.03.2017	4	20.03.2017		
PTRY	Pantry	5	20.03.2017	4	20.03.2017		
REC-E	Reception, Emergency	6	29.05.2019	6	29.05.2019	This Standard Component has been updated	General update following ERG review
RECL-10	Reception/ Clerical, 10m2	5	20.03.2017	5	20.03.2017		
RECL-12	Reception/ Clerical, 12m2	5	20.03.2017	4	20.03.2017		
RECL-15	Reception/ Clerical, 15m2	5	20.03.2017	5	20.03.2017		
REPR	Reporting Room	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
REPW	Reporting Workstation	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
SCRB-4	Scrub Up, 4m2	1	02.07.2018	1	02.07.2018		
SECL	Seclusion Room	5	02.07.2018	5	02.07.2018		
SECR-10	Security Room, 10m2	3	20.03.2017	3	20.03.2017		
SHD	Shower - Accessible, 4m2	5	20.03.2017	4	20.03.2017		
SHPT	Shower - Patient, 4m2	5	20.03.2017	7	20.03.2017		
SHST	Shower - Staff, 3m2	5	20.03.2017	5	20.03.2017		
SPECC	Specimen Collection Bay	3	20.03.2017	4	20.03.2017		
SPECT-CT	SPECT-CT Imaging Room	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
SPECT-CTCR	SPECT-CT Control Room	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
SPREC	Specimen Reception/ Sort/ Preparation	3	20.03.2017	4	20.03.2017		
SRM-15	Staff Room, 15m2	5	20.03.2017	5	20.03.2017		
SRM-18	Staff Room, 18m2	5	20.03.2017	4	20.03.2017		
SRM-25	Staff Room, 25m2	5	20.03.2017	4	20.03.2017		
SRM-35	Staff Room, 35m2	5	20.03.2017	4	20.03.2017		
SSTN-10	Staff Station, 10m2	5	20.03.2017	4	20.03.2017		
SSTN-14	Staff Station, 14m2	5	20.03.2017	4	20.03.2017		
SSTN-20	Staff Station, 20m2	5	20.03.2017	4	20.03.2017		
STAD	Store - Accountable Drugs	3	20.03.2017	3	20.03.2017		
STBK-20	Store - Bulk, 20m2	3	20.03.2017	4	20.03.2017		
STBK-40	Store - Bulk, 40m2	3	20.03.2017	3	20.03.2017		
STCL	Store - Cleaners	5	20.03.2017	5	20.03.2017		
STDR-10	Medication Room, 10m2	3	20.03.2017	3	20.03.2017		
STEQ-14	Store - Equipment, 14m2	5	20.03.2017	4	20.03.2017		
STEQ-20	Store - Equipment, 20m2	5	20.03.2017	5	20.03.2017		
STFS-10	Store - Files, 10m2	5	20.03.2017	6	20.03.2017		
STFS-20	Store - Files, 20m2	5	20.03.2017	5	20.03.2017		
STGN-8	Store - General, 8m2	5	20.03.2017	3	20.03.2017		
STGN-9	Store - General, 9m2	5	20.03.2017	3	20.03.2017		
STPP	Store - Patient Property	5	20.03.2017	5	20.03.2017		
STPS-10	Store - Photocopy/ Stationery, 10m2	5	20.03.2017	3	20.03.2017		
STPS-8	Store - Photocopy/ Stationery, 8m2	5	20.03.2017	4	20.03.2017		
STRT	Stress Testing	3	20.03.2017	3	20.03.2017		
STSS-20	Store - Sterile Stock, 20m2	4	02.07.2018	5	02.07.2018		
STSS-CC	Store - Sterile Stock, Central Core	1	02.07.2018	1	02.07.2018		

AusHFG Standard Components Document Register

13/05/2019



SC= Standard Component RDS = Room Data Sheet RLS = Room Layout Sheet

No. of Standard Components = 251

Code	SC Name	RDS Revision	RDS Date	RLS Revision	RLS Date	Status	Changes since last AusHFG Standard Components Document Register issue
TRIAGE-1	Triage Assessment Room, Emergency - Type 1	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
TRIAGE-2	Triage Assessment Room, Emergency - Type 2	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
TRMT	Treatment Room	5	20.03.2017	7	20.03.2017		
TRMT-CHE	Treatment Bay - Chemotherapy, 9m2	3	20.03.2017	4	20.03.2017		
TRMT-RD-A	Treatment Bay - Renal Dialysis Type A	4	20.03.2017	4	20.03.2017		
TRMT-RD-B	Treatment Bay - Renal Dialysis Type B	3	20.03.2017	2	23.05.2006		
ULTR	Ultrasound Room	4	29.05.2019	5	29.05.2019	This Standard Component has been updated	General update following ERG review
ULTR-PR	Ultrasound Room - Procedures	1	29.05.2019	1	29.05.2019	This Standard Component is new	First issue
WAIT-10	Waiting, 10m2	5	20.03.2017	6	20.03.2017		
WAIT-20	Waiting, 20m2	5	20.03.2017	4	20.03.2017		
WAIT-30	Waiting, 30m2	5	20.03.2017	4	20.03.2017		
WAIT-50	Waiting, 50m2	5	20.03.2017	4	20.03.2017		
WAIT-SEC	Waiting - Secure, 6m2	5	20.03.2017	3	20.03.2017		
WAIT-SUB	Waiting - Sub, 5m2	5	20.03.2017	3	20.03.2017		
WCAC	Toilet - Accessible, 6m2	5	20.03.2017	6	20.03.2017		
WCPT	Toilet - Patient, 4m2	3	20.03.2017	9	20.03.2017		
WCPU-3	Toilet - Public, 3m2	5	20.03.2017	4	20.03.2017		
WCST	Toilet - Staff, 3m2	5	20.03.2017	4	20.03.2017		
WTPL	Water Treatment Plant Room	3	20.03.2017	3	20.03.2017		

The following Standard Components have been retired:

AMBTR	Ambulance Triage	3	20.03.2017	3	20.03.2017	This Standard Component has been retired	
DPRO	Daylight Processing	3	20.03.2017	3	20.03.2017	This Standard Component has been retired	
FPVR	Film Processing, Viewing and Reporting	3	20.03.2017	3	20.03.2017	This Standard Component has been retired	
PACS	PACS Storage and Viewing	4	20.03.2017	3	20.03.2017	This Standard Component has been retired	
PBC-20	Patient Bay - Critical, 20m2	3	20.03.2017	3	20.03.2017	This Standard Component has been retired	
PBCE-20	Patient Bay - Critical (Enclosed), 20m2	4	20.03.2017	2	20.03.2017	This Standard Component has been retired	
PREP-S	Preparation/ Set-up Room (Imaging)	3	20.03.2017	3	20.03.2017	This Standard Component has been retired	
SHDEC	Shower - Decontamination, 8m2	3	20.03.2017	3	20.03.2017	This Standard Component has been retired	
STDE	Store - Disaster Equipment	5	20.03.2017	4	20.03.2017	This Standard Component has been retired	
XRRR	X-Ray Viewing and Reporting	4	20.03.2017	5	20.03.2017	This Standard Component has been retired	