

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 1540</b>
<b>Room Name</b>	<b>Bay - Meal Trolley, 4m2</b>	<b>Room Code: BMT-4</b>
<b>Net Room Area Briefed</b>	4.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Briefed Area</b>	4.00 M2	
<b>Minimum Dimension</b>	1200.0 MM	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	N/A	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>An open storage bay for holding meal trolleys during meal delivery and collection times. Meal service trolleys to be confirmed; special power may be required for Cook/chill rethermalisation trolleys.</p> <p>Special Design Requirements: The Bay should be deep enough to ensure trolleys do not impede corridor circulation; minimum depth 1200mm.</p>	
<b>Amendment</b>	<p>24.03.05, - First Draft                  15.12.08, - 2008 AUSHFG Review; min dimension added; FF, FE &amp; services remarks added</p>	

**Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Default = vinyl: or consistent with adjacent area
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		Default = vinyl: or consistent with adjacent area
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to Acrovyn
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		Equal to 'Acrovyn'

**Fittings and Furniture (FF)**

ID	Description	Category	Group	Qty	Selection / Remarks
23910	Trolley: tray	Furniture/ Fitting	3	1	as required

**Fixtures, Equipment and associated Services (FE)**

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection / Remarks
21585	Trolley: food delivery, hot/ cold	3	1	yes	___	___	___	___	___	___	___	as required

**Services**

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		consistent with adjacent area
6000	General fluorescent	Lighting		consistent with adjacent area

Department | Standard Components  
Room Name | Bay - Meal Trolley, 4m2

Room Tag: 1540  
Room Code: BMT-4

ID	Description	Service Category	Qty	Selection / Remarks
9065	GPO: Special: 3 phase	Power	1	1 per food delivery or rethermalisation trolley, as required