

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 1630</b>
<b>Room Name</b>	<b>Bay - Resuscitation Trolley</b>	<b>Room Code: BRES</b>
<b>Net Room Area Briefed</b>	1.5 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Briefed Area</b>	1.50 M2	
<b>Minimum Dimension</b>	800.0 MM	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	N/A	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>A recessed bay to provide supervised holding of the resuscitation trolley and equipment. The bay should be located close to a Staff Station. Rapid emergency access to the trolley and from this area to Patient Areas is essential.</p> <p>Special Design Requirements: The Bay shall be a minimum of 800mm deep.</p>	
<b>Amendment</b>	<p>31.10.03, - First Draft                  15.12.08, - 2008 AUSHFG Review; area &amp; description modified; FF, FE &amp; services modified</p>	

**Room Fabric and outline specifications**

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		equal to 'Acrovyn'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		as required; equal to 'Acrovyn'

**Fittings and Furniture (FF)**

ID	Description	Category	Group	Qty	Selection / Remarks
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over trolley, optional
18800	Trolley: resuscitation, adult	Furniture/ Fitting	3	1	

**Fixtures, Equipment and associated Services (FE)**

**Services**

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		consistent with adjacent areas
6000	General fluorescent	Lighting		consistent with adjacent areas

Department | Standard Components  
Room Name | Bay - Resuscitation Trolley

Room Tag: 1630  
Room Code: BRES

ID	Description	Service Category	Qty	Selection / Remarks
9011	GPO: Emergency power, double	Power	2	for recharging emergency equipment