

Department	Standard Components	Room Tag: 1750
Room Name	Change Cubicle - Accessible	Room Code: CHPT-D
Net Room Area Briefed	4.0 M2	
No of Rooms	1	
Subtotal of Briefed Area	4.00 M2	
Hours of Operation	24 Hours	
Occupancy	1 patient	
Also covers these Rooms		
Description/ Special Requirements	A screened area for disabled patients to undress from street clothes into a hospital gown, as appropriate, prior to examination or treatment. Following examination or treatment, the patient will re-dress in street clothes. The Change Cubicle should provide facilities for hanging clothes and a bench for the patient to sit on whilst changing.	
Amendment	31.10.03, - First Draft 15.12.08, - 2008 AUSHFG Review, Description, Fabric, FF & Services amended	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		to both sides of door, if provided
8040	Door protection	Composite	Prefinished PVC	To door frame		if door provided
9001	Doors	Solid Core	Paint	Single leaf		910mm outward opening, Privacy latch, emergency release
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, covered		Default= vinyl: carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl covered, 150 mmH		Default = covered vinyl: unless carpet required
3000	Wall finish	Paint	Acrylic, washable			
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		as required, if no door provided

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1000	Bench seat	Furniture/ Fitting	1	1	
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	optional in lieu of bench
3400	Coathook	Metalwork	1	2	at 1200 AFFL
4700	Curtain track: privacy screen	Metalwork	1	1	or door to cubicle
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	if curtain track provided
8510	Grab Rail: SS	Metalwork	1	1	
13700	Mirror	Metalwork	1	1	

Fixtures, Equipment and associated Services (FE)

Department | Standard Components
 Room Name | Change Cubicle - Accessible

Room Tag: 1750
 Room Code: CHPT-D

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light, outside cubicle entry, optional or shared with a group of change rooms
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light