

Department	Standard Components	Room Tag: 1740
Room Name	Change Cubicle - Patient	Room Code: CHPT
Net Room Area Briefed	2.0 M2	
No of Rooms	1	
Subtotal of Briefed Area	2.00 M2	
Hours of Operation	24 Hours	
Occupancy	1 patient	
Also covers these Rooms		
Description/ Special Requirements	<p>The change cubicle is provided for ambulant patients to undress from street clothes into a hospital gown, as appropriate, prior to examination or treatment. Following examination or treatment, the patient will re-dress in street clothes. The Change Cubicle should provide facilities for hanging clothes and a bench for the patient to sit on whilst changing.</p> <p>Special Requirements: Where two-way access is provided the corridor side door should be lockable from the inside to provide security to patient belongings.</p>	
Amendment	<p>31.10.03, - First Draft 15.12.08, - 2008 AUSHFG Review, Description, Fabric, FF & Services amended</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		if door provided
9001	Doors	Solid Core	Paint	Single leaf		optional, 910mm outward opening, privacy latch, with emergency release
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Default= vinyl, carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		Default= vinyl coved, feather edge acceptable if carpet used
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1000	Bench seat	Furniture/ Fitting	1	1	
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	optional in lieu of bench
3400	Coathook	Metalwork	1	2	
4700	Curtain track: privacy screen	Metalwork	1	1	or door to cubicle
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	if curtain track provided
13700	Mirror	Metalwork	1	1	

Fixtures, Equipment and associated Services (FE)

Department | Standard Components
 Room Name | Change Cubicle - Patient

Room Tag: 1740
 Room Code: CHPT

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light, outside cubicle entry, optional - may be shared between a group of rooms
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light