

Department	Standard Components	Room Tag: 2040
Room Name	Consult Room	Room Code: CONS
Net Room Area Briefed	12.0 M2	
No of Rooms	1	
Subtotal of Briefed Area	12.00 M2	
Hours of Operation	24 Hours	
Occupancy	1 patient; 1-2 staff and on occasions an escort/ interpreter	
Also covers these Rooms		
Description/ Special Requirements	<p>The Consult Room will provide for private consultation and examination of patients with or without support persons present. A second egress door may be required for staff safety and security.</p> <p>Acoustics: Sound attenuation level - high; Acoustic privacy essential.</p> <p>Body Protected electrical area</p>	
Amendment	<p>10.10.03, - First Draft 21.03.05, - BOB user review, doors modified 15.12.08, - 2008 AUSHFG Review; special requirements added, FF and Services amended</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf		egress door, optional
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		910/1400mm clear opening, half door optional
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Default = vinyl: Carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		Default = coved skirting : or vinyl featheredge skirting over carpet
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		Default = vinyl: tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	optional
1470	Bracket: sharps	Furniture/ Fitting	2	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	optional
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
2600	Chair: visitor, office	Furniture/ Fitting	3	3	
3400	Coathook	Metalwork	1	2	

Department **Standard Components**
 Room Name **Consult Room**

Room Tag: **2040**
 Room Code: **CONS**

ID	Description	Category	Group	Qty	Selection / Remarks
4600	Curtain track: bed screen	Metalwork	1	1	to exam couch
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
5900	Desk	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to hand basin
13700	Mirror	Metalwork	1	1	for patient changing
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	optional
17360	Pinboard: fabric covered	Furniture/ Fitting	1	1	over desk, optional
19140	Scales: weighing, floor	Furniture/ Fitting	3	1	
19700	Sharps bin	Furniture/ Fitting	3	1	Wall mounted
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over desk, optional
21030	Sphygmomanometer: wall mounted	Furniture/ Fitting	3	1	
21950	Suction adapter	Furniture/ Fitting	3	1	optional
22000	Suction bottle	Furniture/ Fitting	3	1	optional
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	elbow action levers
11400	Computer: PC & monitor	3	1	yes	yes	___	___	___	___	___	___	to desk, optional
15900	Diagnostic set: wall mounted	3	1	yes	___	___	___	___	___	___	___	optional
20350	Examination couch: electric	3	1	yes	___	___	___	___	___	___	___	
31701	Light: examination, wall mount	1	1	yes	___	___	___	___	___	___	___	Default= wall mounted: or ceiling mounted, optional
54520	Telephone: handset, handsfree	3	1	___	yes	___	___	___	___	___	___	
68700	Xray viewer: 2 screen	1	1	yes	___	___	___	___	___	___	___	

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting	1	
7020	Medical Air (MA)	Medical Gases	1	optional
7000	Oxygen (O2)	Medical Gases	1	optional
7040	Suction	Medical Gases	1	optional
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	2	workstation / desk area
9001	GPO: Double	Power	1	patient examination area

Department | Standard Components
 Room Name | Consult Room

Room Tag: 2040
 Room Code: CONS

ID	Description	Service Category	Qty	Selection / Remarks
9011	GPO: Emergency power, double	Power	1	patient examination area
9000	GPO: Single	Power	1	low level for electric couch
9000	GPO: Single	Power	1	Diagnostic set
9060	GPO: Special: for equipment	Power	2	XR.V, exam light
10005	Duress alarm	Security	1	under O/H shelving
11000	Wall panel	Services Panels	1	