

# Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag:</b> 2310
<b>Room Name</b>	<b>Echocardiography - Trans-oesophageal</b>	<b>Room Code:</b> ECHO
<b>Area</b>	30.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	30.0 M2	
<b>Hours of Operation</b>	Available 24 Hours	
<b>Occupancy</b>	1 patient; 1 - 2 staff	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	Room for diagnostic echocardiography procedures including trans-oesophageal echocardiography. Echocardiography procedures may be performed under local anaesthesia. The Echocardiography room should be located close to patient toilet and change rooms.	
	Acoustics: Acoustic privacy required	
	Body Protected electrical area	
<b>Amendment</b>	07.04.05, - First Draft	

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin; tiles also acceptable

## Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	patient services panel
1050	Bench: laminate	Furniture/ Fitting	1	1	
1650	Chair: client	Furniture/ Fitting	3	1	
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
3350	Clock: battery operated	Furniture/ Fitting	3	1	
3400	Coathook	Metalwork	1	1	
4360	Cupboard: door ht adj. shelves	Furniture/ Fitting	1	1	
4410	Cupboard: under bench	Furniture/ Fitting	1	1	adjustable shelves
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench
4700	Curtain track: privacy screen	Metalwork	1	1	to entry door

# Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department **Standard Components**  
 Room Name **Echocardiography - Trans-oesophageal**

Room Tag: **2310**  
 Room Code: **ECHO**

ID	Description	Category	Group	Qty	Selection
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to entry door
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
7500	Examination couch	Furniture/ Fitting	3	1	
8100	Footstool	Furniture/ Fitting	3	1	
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	patient services panel
21950	Suction adapter	Furniture/ Fitting	3	1	patient services panel
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

## Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	___	
19200	IMG: Echocardiography machine	3	1	yes	___	___	___	___	___	___	___	
31700	Light: examination, ceiling	1	1	yes	___	___	___	___	___	___	___	optional
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	to bench
68700	Xray viewer: 2 screen	1	1	yes	___	___	___	___	___	___	___	optional

## Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	
5000	Airconditioning	HVAC		
6110	Downlights: dimmable	Lighting		
6001	General: colour corrected	Lighting		
8080	Emergency call	Nurse Call	1	
8005	Patient call handset	Nurse Call	2	1- bed area; 1 - exam couch; bed and couch may share one point if handset will reach both
8000	Patient/ Staff call	Nurse Call	2	1- bed area; 1 - exam couch; bed and couch may share one point if handset will reach both
8010	Staff/ Nurse assist call	Nurse Call	1	
9040	Body protected	Power		
9001	GPO: Double	Power	4	
9010	GPO: Emergency power, single	Power	4	patient services panel
9000	GPO: Single	Power	2	to exam couch
9060	GPO: Special: for equipment	Power	3	Echocardiography machine, exam light, XRV