

Department	Standard Components	Room Tag: 2630
Room Name	Laundry - Patient	Room Code: LAUN-PT
Net Room Area Briefed	6.0 M2	
No of Rooms	1	
Subtotal of Briefed Area	6.00 M2	
Hours of Operation	24 Hours	
Occupancy	1 - 2	
Also covers these Rooms		
Description/ Special Requirements	Domestic style laundry for patient use, wheelchair accessible. The room will include a bench, laundry tub, domestic washing machine and dryer and ironing facilities.	
Amendment	14.03.05, - First Draft 15.12.08, - 2008 AUSHFG Review; Services amended	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5021	Ceiling	Plasterboard	Paint, washable	Water resistant, flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening, lockable
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		Observation window, optional
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		default= vinyl: tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	with inset laundry tub, open under part
1460	Bracket: wall	Metalwork	1	1	for dryer
1505	Cabinet: ironing board	Furniture/ Fitting	1	1	lockable, with integral ironing board
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench
23956	Trolley: laundry, basket	Furniture/ Fitting	3	1	under bench

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection / Remarks
18400	Dryer: tumble, domestic	3	1	yes	___	___	___	___	___	___	___	wall mounted
29200	Iron: electric	3	1	yes	___	___	___	___	___	___	___	inside cupboard

Department **Standard Components**
 Room Name **Laundry - Patient**

Room Tag: **2630**
 Room Code: **LAUN-PT**

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection / Remarks
49400	Sink: laundry, single	1	1	___	___	yes	opt	opt	yes	yes	___	with overflow drain, warm water, sinlge mixer to tub optional
60650	Washing machine: domestic	3	1	yes	___	yes	yes	___	yes	yes	___	heavy duty

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		extra steam/ heat extraction to room
5037	Special exhaust: dryer	HVAC	1	
4005	Cold water	Hydraulics	1	to washing machine
4033	Floor waste	Hydraulics	1	
4000	Hot water: outlet	Hydraulics	1	to washing machine
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	1	30mA RCD protection, above bench
9000	GPO: Single	Power	3	washer, dryer, ironing cabinet, 30mA RCD protection