

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 3120
Room Name	Neonatal Bay - Intensive Care	Room Code: NBICU
Area	12.0 M2	
No of Rooms	1	
Subtotal of Area		
Hours of Operation	24 Hours	
Occupancy	1 baby; 2-3 staff; 1-2 parents	
Also covers these Rooms		
Description/ Special Requirements	<p>A single bay for neonates requiring Intensive Care nursing and medical treatment. The Bay will include provisions for charting and storage. A staff handwash basin (Type A) should be provided within close access of each Bay. An external outlook is required.</p> <p>Acoustics: Sound attenuation level - high; Acoustic privacy is required to perimeter walls</p> <p>Cardiac Protected electrical area</p>	
Amendment	<p>24.01.05, - First Draft</p> <p>28.02.05, - BOB User review, GPOs modified</p>	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7030	Observation	Alum/ glass	Powdercoat	Internal window, door height		with integral venetians, optional
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3060	Wall finish	Vinyl	Prefinished	Splashback		to basin, tiles also acceptable
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		equal to 'Acrovyn'
7001	Windows					External outlook to the area required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	3	
1050	Bench: laminate	Furniture/ Fitting	1	1	
1252	Blind: Venetian integral	Furniture/ Fitting	1	1	to observation window if provided
1465	Bracket: suction bottle	Furniture/ Fitting	2	3	
2655	Chair: visitor	Furniture/ Fitting	3	1	
4430	Cupboard: drawer unit	Furniture/ Fitting	1	1	under bench
4410	Cupboard: under bench	Furniture/ Fitting	1	1	adjustable shelves
4600	Curtain track: bed screen	Metalwork	1	1	to full bay
5000	Curtain: bed screen	Furniture/ Fitting	3	1	

Australasian Standard Project

Room Data Sheets

Department **Standard Components**
 Room Name **Neonatal Bay - Intensive Care**

Room Tag: **3120**
 Room Code: **NBICU**

ID	Description	Category	Group	Qty	Selection
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
16250	Oxygen flowmeter	Furniture/ Fitting	3	3	
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over bench
22000	Suction bottle	Furniture/ Fitting	3	3	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
3100	Basin: scrub, Type A	1	1	—	—	yes	—	yes	yes	yes	—	in close proximity; refer to BHWS-A (sim)
26000	Humidicrib	3	1	yes	—	—	—	—	—	—	—	
31700	Light: examination, ceiling	1	1	yes	—	—	—	—	—	—	—	

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet for telephone
5000	Airconditioning	HVAC		
6005	Dimmable	Lighting		variable lighting level
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelving
7020	Medical Air (MA)	Medical Gases	3	
7000	Oxygen (O2)	Medical Gases	3	
7040	Suction	Medical Gases	3	
8080	Emergency call	Nurse Call	1	
8010	Staff/ Nurse assist call	Nurse Call	1	
9030	Cardiac protected	Power		
9015	GPO: Cleaner	Power	1	to a group of bays
9010	GPO: Emergency power, single	Power	12	
9060	Special: for equipment	Power	1	exam light
11000	Wall panel	Services Panels	1	flush mounted