

# Australasian Standard Project

## Room Data Sheets

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag: 2580</b>
<b>Room Name</b>	<b>Patient Bay - Acute Treatment, 12 m2</b>	<b>Room Code: PBTR-A12</b>
<b>Area</b>	12.0 M2	
<b>No of Rooms</b>	1	
<b>Subtotal of Area</b>	12.0 M2	
<b>Minimum Dimension</b>	0.0 M2	
<b>Hours of Operation</b>	24 Hours	
<b>Occupancy</b>	1 patient; 1 - 2 staff	
<b>Also covers these Rooms</b>		
<b>Description/ Special Requirements</b>	<p>The Patient Bed Bay Acute Treatment may be used for assessment and treatment of patients with acute conditions and will be located within the Emergency Unit. The Bay may have partition side walls; glazing is recommended. The Patient Bay will have close access to a staff handwashing basin.</p> <p>Body Protected electrical area</p>	
<b>Amendment</b>	<p>20.11.03, - First Draft 01.03.05, - BOB User review, shelf &amp; N20 added</p>	

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, covered		
7055	Observation	Alum/ glass	Anodised	Internal window, double glazed		to partition walls, if provided
2000	Skirting	Vinyl	Prefinished	Floor vinyl covered, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3092	Wall protection	MDF	Laminate	Bed protection wall panel		
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		As required, Equal to 'Acrovyn'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		As required, Equal to 'Acrovyn'

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
150	Air flowmeter	Furniture/ Fitting	3	1	
700	Bed: inpatient, manual	Furniture/ Fitting	3	1	
1090	Bench: laminate, free standing	Furniture/ Fitting	3	1	optional
1252	Blind: Venetian integral	Furniture/ Fitting	1	2	to internal windows if provided
15100	Bracket: monitor	Furniture/ Fitting	3	1	optional, may have ergonomic arm
1470	Bracket: sharps	Furniture/ Fitting	2	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	
2650	Chair: visitor, patient	Furniture/ Fitting	3	1	
4600	Curtain track: bed screen	Metalwork	1	1	

# Australasian Standard Project

## Room Data Sheets

Department **Standard Components**  
 Room Name **Patient Bay - Acute Treatment, 12 m2**

Room Tag: **2580**  
 Room Code: **PBTR-A12**

ID	Description	Category	Group	Qty	Selection
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
10700	IV hanger for ceiling track	Metalwork	1	1	
11200	IV track: ceiling mounted	Metalwork	1	1	
12900	Louvred panel: for storage-bins	Metalwork	1	2	optional, for storage
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
19700	Sharps bin	Furniture/ Fitting	3	1	
19800	Shelf: laminate	Furniture/ Fitting	1	1	above services panel, optional
21755	Storage bins	Furniture/ Fitting	3	10	optional, for storage on louvred panel
21950	Suction adapter	Furniture/ Fitting	3	2	
22000	Suction bottle	Furniture/ Fitting	3	2	
23952	Trolley: small	Furniture/ Fitting	1	2	1 trolley under bench

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
15900	Diagnostic set: wall mounted	3	1	yes	___	___	___	___	___	___	___	optional
32150	Light: procedure, ceiling		1	yes	___	___	___	___	___	___	___	
36050	Monitor: cardiac	3	1	yes	opt	___	___	___	___	___	___	optional

### Services

ID	Description	Service Category	Qty	Remarks
1120	Monitor connection facilities and cabling	Communications	1	optional, if networked monitoring required
1006	Voice / Data outlet: double	Communications	1	services panel, 1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	services panel
7010	Nitrous Oxide (N2O)	Medical Gases	1	services panel, optional
7000	Oxygen (O2)	Medical Gases	2	services panel
7070	Scavenge	Medical Gases	1	services panel, if N2O provided
7040	Suction	Medical Gases	2	services panel
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9010	GPO: Emergency power, single	Power	4	services panel, 1 for monitor, if required
9000	GPO: Single	Power	3	services panel
9000	GPO: Single	Power	1	for electric bed
9060	Special: for equipment	Power	1	procedure light
11000	Wall panel	Services Panels	1	