

Room Name | Anteroom

Room Number: ANRM

Last modified | 01/03/2016
Briefed Area | 6.00
Remarks
Occupancy | 1 - 2
Hours of Operation | 24 Hours
Acoustics
Description / Special Requirements

Anteroom associated with an Isolation room for maintenance of air pressurisation and for staff and visitors to change and dispose of protective gear used on entering or exit; a staff handwashing basin will be located within the room; glazing is recommended for patient and staff visibility. Pressurisation - negative or positive depending on type of Isolation room Body Protected electrical area

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	To basin; selected material to comply with Infection Control Guidelines
2526	Floor finish	Vinyl	Non-slip	Seamless coved	Under basin; significant change in colour to be avoided
3000	Wall finish	Paint	Acrylic, washable		
2906	Wall finish			Splashback behind basin	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
9002	Door - 910mm	Solid Core/ Glass	Paint	Single leaf, half glazed	From Corridor to Anteroom. Staff movement.
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
2529	Door protection	Composite	Prefinished PVC	To door frame	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-12300	Linen carrier - dirty, single	3	1	
FF-3400	Coathook	1	4	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-6153	Dispenser - moisturiser	2	1	Optional. Depends on Operational Policy.
FF-5578	Trolley - PPE	3	1	
FF-5830	Dispenser - antiseptic hand rub	2	1	
FF-5824	Waste bin - general	3	1	

Room Name | Anteroom

Room Number: ANRM

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Elbow action levers or handsfree optional.

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-5000	Airconditioning		1	
S-5015	Ventilation		1	
S-5019	Exhaust		1	to rangehood
S-6000	General fluorescent		1	
S-6200	Light switches		1	2