

Room Name | Bay - Beverage, Open plan

Room Number: BBEV-OP

Last modified	01/03/2016
Briefed Area	4.00
Remarks	
Occupancy	1-2 intermittently
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	
Description / Special Requirements	<i>The Beverage Bay is an area for preparing and/or heating refreshments, snacks and some meals, washing some utensils, storing food and drink and disposing of food waste (in accordance with food hygiene requirements) in a patient care environment. If an instantaneous boiling water unit is provided, it should be hardwired and access restricted as required. The Beverage Bay may be located with ready access to patient areas, staff rooms, or meeting rooms. The Beverage Bay should be adequately recessed to avoid encroachment into the corridor. Increase room size to 5m² (minimum) for enclosed space.</i>

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
2906	Wall finish			Splashback behind basin	
2535	Wall protection			Corner guards to 900 AFFL	Align heights of corner guards with other corridor elements
5007	Ceiling - Plasterboard	Plasterboard	Paint	Bulkhead	Laminate infill also acceptable. Between above bench joinery and ceiling.
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	Optional, enclosed bay only.
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
2529	Door protection	Composite	Prefinished PVC	To door frame	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	with inset sink/drainage. Length to suit layout, refer RLS or project specific requirements.
FF-19990	Shelving unit - microwave	1	1	over bench, optional
FF-4410	Cupboard - under bench	1	1	lockable as required. Number to suit layout, refer RLS or project specific requirements.
FF-4430	Cupboard - drawer unit	1	1	under bench
FF-4460	Cupboard - wall mounted	1	1	above bench, adjustable shelf; lockable as required. Number to suit layout, refer to

Room Name | Bay - Beverage, Open plan

Room Number: BBEV-OP

AusHFG code	Description	Group	Qty	Comments
				RLS or project specific requirements.
FF-5860	Waste bin - fliptop	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-26801	Dispenser - ice	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	optional; selection of model to comply with infection control requirement
FE-35400	Oven - microwave, domestic	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional
FE-44100	Refrigerator - 250 Litre, domestic	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	or underbench refrigerator
FE-5080	Tapware - Boiling/chilled water unit (comb)	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-5080	Boiling/chilled water unit (comb)	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Tapware: instant hot/cold water tap to bench/sink top.
FE-5785	Sink & drainer - single, 930mmL	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-40403	Tapware - accessible basin mixer	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	4	Bedhead low level, for electric bed
S-9001	GPO: Double	1	1	
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	