

Room Name | Bay - Blanket/ Fluid Warmer

Room Number: BBW

Last modified | 01/03/2016
Briefed Area | 1.00
Remarks
Occupancy
Hours of Operation | 24 Hours
Acoustics
Description / Special Requirements

A Bay for a blanket or combined blanket / fluid warming cabinet. The bay should have close access to patient areas and operating rooms. Assess dimensions of cabinet to ensure space is adequate. When blanket warming is accommodated, ideally located near a Linen Bay.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
2670	Wall protection			Corner guards to 900 AFFL minimum	Align heights of corner guards with other corridor elements
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	Acoustic tiles acceptable.
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-4450	Cabinet - blanket/ fluid warming	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Freestanding

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9010	GPO: Emergency power, single (V)	1	1	monitor
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	