

**Room Name** | **Bay Height/Weight**

**Room Number: BHW**

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	2.00
<b>Remarks</b>	
<b>Occupancy</b>	1-2 intermittently
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	
<b>Description / Special Requirements</b>	An open bay for measuring patients' height and weight either standing or in a wheelchair. Type of weighing scales will depend on service provision. Special design requirements: - The bay should be deep enough to ensure weighing scales do not impede corridor circulation.- Provision of appropriately located power outlets will be required.

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
2670	Wall protection			Corner guards to 900 AFFL minimum	Align heights of corner guards with other corridor elements
2537	Wall protection			Crash rail at 900 AFFL	As required
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	Consistent with adjacent area. Acoustic tiles acceptable.
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	Consistent with adjacent area.
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-7400	Trolley - equipment	3	1	
FF-6192	Stadiometer - wall mounted	3	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-19750	Scales - electronic, standing	3	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Chair or standing and bariatric consideration depends on project specific requirements.

## Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	1	

Room Name | Bay Height/Weight

Room Number: BHW

AusHFG code	Description	Group	Qty	Comments
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	