

**Room Name** | Birthing Room - LDR

**Room Number:** BIRM

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	28.00
<b>Remarks</b>	
<b>Occupancy</b>	1 patient; 1-2 support persons; up to 4 staff
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	Sound attenuation level high, Acoustic privacy is required.
<b>Description or Special Requirements</b>	The Birthing Room LDR provides for the entire process of delivery including patient preparation, relaxation and analgesia during labour, delivery, infant resuscitation, post natal recovery and observation. The Birthing Room shall include a scrub basin. Clinical items such as medical gases and services may be concealed but within easy reach. Acoustics: Sound attenuation level high: Acoustic privacy required Body Protected electrical area

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin
3092	Wall protection	MDF	Laminate	Bed protection wall panel	
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to 'Acrovyn'
9110	Door - 1400mm	Solid Core	Paint	1 1/2 leaf	1400mm clear opening
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate		1	
FF-12450	Locker - bedside		3	
FF-12770	Lounge - 2 1/2 seat		3	
FF-1465	Bracket - suction bottle		2	
FF-1470	Bracket - sharps		2	mounted to trolley
FF-150	Air flowmeter		3	optional
FF-16200	Table - overbed		3	
FF-16250	Oxygen flowmeter		3	
FF-16280	Oxygen / nitrous mixer		3	mobile
FF-19700	Sharps bin		3	on trolley

Room Name | Birthing Room - LDR

Room Number: BIRM

AusHFG code	Description	Group	Qty	Comments
FF-19800	Shelf - laminate	1	1	near basin
FF-21700	Stool - adjustable, mobile, high	3	1	
FF-21950	Suction adapter	3	2	
FF-2200	Chair - recliner	3	1	
FF-22000	Suction bottle	3	2	
FF-23950	Trolley	3	1	
FF-24125	Waste bin - clinical	3	1	
FF-2650	Chair - visitor, patient	3	1	
FF-4330	Cupboard - wardrobe	1	1	
FF-4391	Cupboard - special	1	1	to conceal services
FF-4460	Cupboard - wall mounted	1	2	over bench
FF-4500	Curtain track - ceiling mounted	1	1	to baby resus area
FF-4600	Curtain track - bed screen	1	1	to door entry
FF-480	Bassinet	3	1	
FF-4900	Curtain track - window	1	1	
FF-5000	Curtain - bed screen	3	2	to door entry and resus trolley
FF-5410	Curtain - window, drapes	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-710	Bed - birthing, manual	3	1	
FF-5825	Bracket - patient entertainment, ceiling	1	1	
FF-5824	Waste bin - general	3	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-26950	Infant resuscitaire	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-3100	Basin - scrub, Type A	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-A (sim)
FE-31750	Light - examination, mobile	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-32700	Light - operating, single, mobile	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Room Name | Birthing Room - LDR

Room Number: BIRM

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-35850	Monitor - foetal, CTG	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	mobile
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FF-5547	Patient entertainment	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6050	Special: reading	Up/down light
S-6110	Downlights: dimmable	optional

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	8	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	6	monitor
S-9001	GPO: Double	1	4	
S-9040	Body protected	1	1	
S-9060	GPO: Special: for equipment	1	1	TV, ceiling
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-1090	TV: MATV	1	1	
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	3	
S-6050	Special: reading	2	1	Up/down light
S-6110	Downlights: dimmable	1	1	optional
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light

**Room Name | Birthing Room - LDR**
**Room Number: BIRM**

AusHFG code	Description	Group	Qty	Comments
S-2072	Scavenge Outlet	1	1	and controls, on wall, optional
S-7000	Oxygen (O2)	1	3	
S-7010	Nitrous Oxide (N2O)	1	1	services panel
S-7020	Medical Air (MA)	1	2	
S-7040	Suction	1	2	
S-7070	Scavenge	1	1	services panel
S-11000	Wall panel	2	1	patient services panels