

**Room Name** | Bay - Mobile Equipment, 4m2

**Room Number:** BMEQ-4

**Last modified** | 01/03/2016  
**Briefed Area** | 4.00  
**Remarks**  
**Occupancy**  
**Hours of Operation** |  24 Hours  
**Acoustics**  
**Description / Special Requirements**

*An open storage bay for one or more items of mobile equipment in frequent use which may include wheelchairs, mobile scales, commode chairs, patient lifting devices or other mobile equipment. Special Design Requirements: The Bay should be deep enough to ensure equipment stored does not impede corridor circulation; a depth range from 800mm to 1500mm is recommended, depending on equipment to be stored. If imaging equipment is to be stored add 2m2 to bay. Electrical equipment that requires recharging may be stored in this space whilst recharging, therefore provision of appropriately located power outlets will be required.*

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Default = vinyl: or carpet also acceptable
3000	Wall finish	Paint	Acrylic, washable		
2538	Wall protection			Crash rail at 350mm AFFL	
4022	Wall protection	Composite	Prefinished PVC	Crash rail at 350 AFFL	Optional; Equal to 'Acrovyn'
2535	Wall protection			Corner guards to 900 AFFL	
2537	Wall protection			Crash rail at 900 AFFL	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Default = vinyl: or featheredge vinyl skirting over carpet

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-7200	Hook - equipment	1	1	
FF-17200	Slide boards - patient	3	1	

## Fixtures, Equipment and associated Services

### Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

### Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	2	
S-5000	Airconditioning	1	1	

Room Name | Bay - Mobile Equipment, 4m2

Room Number: BMEQ-4

AusHFG code	Description	Group	Qty	Comments
S-6000	General fluorescent	1	1	