

Room Name | Bay - Resuscitation Trolley

Room Number: BRES

Last modified | 01/03/2016
Briefed Area | 1.50
Remarks
Occupancy
Hours of Operation | 24 Hours
Acoustics
Description / Special Requirements

A recessed bay to provide supervised holding of the resuscitation trolley and equipment. The bay should be located close to a Staff Station. Rapid emergency access to the trolley and from this area to Patient Areas is essential. Special Design Requirements: The Bay shall be a minimum of 800mm deep.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
2538	Wall protection			Crash rail at 350mm AFFL	
2535	Wall protection			Corner guards to 900 AFFL	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-18800	Trolley - resuscitation, adult	3	1	
FF-22070	Suction - twin-o-vac unit	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-15500	Defibrillator	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-5878	ECG machine, on trolley	3	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-2806	Trolley; medical equipment	3	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9011	GPO: Emergency power, double (H)	1	2	for refrigerator

Room Name | Bay - Resuscitation Trolley

Room Number: BRES

AusHFG code	Description	Group	Qty	Comments
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	