

**Room Name** | Bay - Vending Machine, 3m2

**Room Number:** BVM-3

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	3.00
<b>Remarks</b>	
<b>Occupancy</b>	1 - 2 intermittently
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> Available 24 Hours
<b>Acoustics</b>	
<b>Description / Special Requirements</b>	A recessed bay off corridor or a public area for vending machines. Add 1.5m2 per additional vending machine.

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	consistent with adjacent area
3000	Wall finish	Paint	Acrylic, washable		
2535	Wall protection			Corner guards to 900 AFFL	
2709	Ceiling	Acoustic	Prefinished	Drop-in tiles	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	consistent with adjacent area
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	consistent with adjacent area

## Fittings and Furniture

### Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-58800	Vending machine - cold drinks	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Type to be project specific.
FE-59000	Vending machine - snacks	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Type to be project specific.

## Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single		1	2 Bedhead low level, for electric bed
S-1005	Voice / Data outlet: single		1	2 in ceiling for data projector; optional
S-5000	Airconditioning		1	
S-6000	General fluorescent		1	