

**Room Name** | Change Room - Patient (Male/Female)

**Room Number:** CHPT-12

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	12.00
<b>Remarks</b>	
<b>Occupancy</b>	Up to 3
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	
<b>Description / Special Requirements</b>	<i>The Patient Change areas are provided for patients to change into gowns, to store their street clothing and to perform personal ablutions. Change Rooms should be divided into Male and Female areas on a proportional basis and will include Change Cubicle, Toilet, handbasin and lockers for secure storage of personal property. Acoustics: Sound attenuation level - medium; acoustic privacy required. Body Protected Electrical Area</i>

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Default= vinyl, carpet also acceptable
3000	Wall finish	Paint	Acrylic, washable		
3000	Wall finish	Paint	Acrylic, washable		
2727	Wall finish			Splashback	To basin. Selection of material to comply with Part D Infection Prevention and Control AusHFG.
5030	Ceiling - Plasterboard	Plasterboard	Prefinished	Drop-in tiles, 600x1200	
9001	Door - 1100mm	Solid Core	Paint	Single leaf	optional, 910mm outward opening, privacy latch, with emergency release
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
2529	Door protection	Composite	Prefinished PVC	To door frame	To be decided at project level.
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Default= vinyl coved, feather edge acceptable if carpet used

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1000	Bench seat	1	1	To change cubicle. Or chair, consider weight capacity.
FF-12300	Linen carrier - dirty, single	3	1	
FF-12509	Locker - 2 tier	3	4	16 half lockers or quarter lockers.
FF-12600	Locker - 4 tier (1/4 size)	3	2	
FF-13700	Mirror	1	1	
FF-19100	Waste bin - sanitary	3	1	To Female Change Rooms. Optional, depends on Waste Management Policy.

**Room Name** | Change Room - Patient (Male/Female)

**Room Number:** CHPT-12

AusHFG code	Description	Group	Qty	Comments
FF-19910	Shelf - vanity	1	1	Above basin. Or integrated with basin.
FF-23610	Partitions - toilet	1	1	
FF-2650	Chair - visitor, patient	3	1	
FF-3350	Clock - battery operated	3	1	Optional
FF-3400	Coathook	1	2	
FF-6154	Dispenser - paper/ hand towel	2	1	
FF-6156	Dispenser - soap	2	1	
FF-6160	Dispenser - toilet paper	1	1	
FF-8390	Trolley - gowns	3	1	
FF-8400	Grab rail - WC	1	2	Ambulant provision.
FF-5824	Waste bin - general	3	1	
FF-2740	Partitions - change cubicle	1	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2850	Basin - handwash, Type C (with vanity)	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Or ensuite basin with integral shelf for patient belongings.
FE-55605	Toilet suite - patient	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	1	
S-9040	Body protected	1	1	
S-4033	Floor waste	1	1	
S-5000	Airconditioning	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	

Room Name | **Change Room - Patient (Male/Female)**Room Number: **CHPT-12**

AusHFG code	Description	Group	Qty	Comments
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	2	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light