

Room Name | Change Cubicle - Accessible

Room Number: CHPT-D

Last modified | 01/03/2016
Briefed Area | 4.00
Remarks
Occupancy | 1 patient
Hours of Operation | 24 Hours
Acoustics
Description / Special Requirements

A screened area for disabled patients to undress from street clothes into a hospital gown, as appropriate, prior to examination or treatment. Following examination or treatment, the patient will re-dress in street clothes. The Change Cubicle should provide facilities for hanging clothes and a bench or chair for the patient to sit on whilst changing. Space allows for an independent disabled person and staff assistance if required. Where rooms serve a Day Surgery service locker space may be needed.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Default= vinyl: carpet also acceptable
3000	Wall finish	Paint	Acrylic, washable		
2683	Wall protection			Corner guards to 900 AFFL maximum	
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
9001	Door - 1100mm	Solid Core	Paint	Single leaf	Optional. Curtain across doorway also acceptable.
2529	Door protection	Composite	Prefinished PVC	To door frame	To be decided at project level.
2712	Door protection			Protection plate to 900 AFFL	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Default = coved vinyl: unless carpet required

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1000	Bench seat		1	Optional in lieu of chair.
FF-13700	Mirror		1	
FF-2650	Chair - visitor, patient		3	optional in lieu of bench; consider weight capacity of chair.
FF-3400	Coathook		1	2 at 1200 AFFL for wheelchair users
FF-4700	Curtain track - privacy screen (straight)		1	optional depending on if door provided
FF-5250	Curtain - privacy screen		3	optional depending on if door provided
FF-8510	Grab Rail - SS		1	

Fixtures, Equipment and associated Services

Service Requirements

Room Name | Change Cubicle - Accessible

Room Number: CHPT-D

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light