

Room Name | Change Cubicle - Patient

Room Number: CHPT

Last modified	01/03/2016
Briefed Area	2.00
Remarks	
Occupancy	1 patient
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	
Description / Special Requirements	<i>The change cubicle is provided for ambulant patients to undress from street clothes into a hospital gown, as appropriate, prior to examination or treatment. Following examination or treatment, the patient will re-dress in street clothes. The Change Cubicle should provide facilities for hanging clothes and a bench for the patient to sit on whilst changing. Special Requirements: Where two-way access is provided the corridor side door should be lockable from the inside to provide security to patient belongings. Where rooms serve a Day Surgery service locker space may be needed.</i>

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Default= vinyl, carpet also acceptable
3000	Wall finish	Paint	Acrylic, washable		
2683	Wall protection			Corner guards to 900 AFFL maximum	
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
9001	Door - 1100mm	Solid Core	Paint	Single leaf	Optional. Curtain across doorway also acceptable.
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
2529	Door protection	Composite	Prefinished PVC	To door frame	To be decided at project level.
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Default= vinyl coved, feather edge acceptable if carpet used

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1000	Bench seat	1	1	Optional in lieu of chair.
FF-13700	Mirror	1	1	for patient changing
FF-2650	Chair - visitor, patient	3	1	optional in lieu of bench; consider weight capacity of chair.
FF-3400	Coathook	1	2	at 1200 AFFL for wheelchair users
FF-4700	Curtain track - privacy screen (90 deg)	1	1	
FF-5250	Curtain - privacy screen	3	1	

Fixtures, Equipment and associated Services

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	

Room Name | Change Cubicle - Patient

Room Number: CHPT

AusHFG code	Description	Comments
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light