

**Room Name** | Clean-Up Room - Shared, 15m2

**Room Number:** CLUP-15

**Last modified** 01/03/2016

**Briefed Area** 15.00

**Remarks**

**Occupancy**

**Hours of Operation**

**Acoustics**

**Description or Special Requirements**

1 - 2

☒ 24 Hours

*The Clean-Up Room, Shared is used for rinsing and cleaning of medical equipment or endoscopes used in the Operating Rooms or Procedure Rooms. Low temperature sterilisation of endoscopes may also be undertaken in this room. The shared Clean-up Room should be located between two Minor Operating Rooms or Procedures rooms where endoscopy procedures are undertaken.*

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL	
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	1100 mm clear opening to ORs, double swing, sliding cover to observation panel
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1010	Bench - stainless steel	1	1	with wet edge and inset sinks
FF-1050	Bench - laminate	1	1	
FF-1470	Bracket - sharps	2	1	
FF-150	Air flowmeter	3	1	for tube drying
FF-19810	Shelf - SS, over	1	1	over sink bench
FF-19820	Shelf - SS, under	1	1	under sink bench
FF-21950	Suction adapter	3	1	for tube cleaning
FF-24125	Waste bin - clinical	3	1	
FF-4430	Cupboard - drawer unit	1	3	under dry bench
FF-4460	Cupboard - wall mounted	1	2	over dry bench
FF-6152	Dispenser - disposable glove	2	2	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin

Room Name | Clean-Up Room - Shared, 15m2

Room Number: CLUP-15

AusHFG code	Description	Group	Qty	Comments
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-5824	Waste bin - general	3	1	
FF-44614	Overbench single door (600hx425wx350d)	1	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-49100	Sink - 750x500x300D	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	hot water
FE-49800	Sink - flushing rim	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	in bench
FE-52450	Steriliser - low temperature, peracetic acid	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	optional
FE-4045	Tapware - elbow mixer		1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	1	
S-9011	GPO: Emergency power, double (H)	1	1	for refrigerator
S-9060	GPO: Special: for equipment	1	1	TV, ceiling
S-4000	Hot water: outlet	1	1	to washing machine
S-4010	Cold water: outlet	1	1	to washing machine
S-4033	Floor waste	1	1	
S-4037	Tundish drain	1	1	for low temp steriliser, optional
S-5000	Airconditioning	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	3	
S-6055	Special: task light, built in	1	3	under O/H cupboards

Room Name | Clean-Up Room - Shared, 15m2

Room Number: CLUP-15

AusHFG code	Description	Group	Qty	Comments
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	