

**Room Name** | Consult Room

**Room Number:** CONS

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	12.00
<b>Remarks</b>	<i>For bariatric consult requirements refer to Treatment Room options</i>
<b>Occupancy</b>	<i>1 patient: 1-2 staff, 1-2 visitors</i>
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	<i>Sound attenuation level high, Acoustic privacy is required.</i>
<b>Description / Special Requirements</b>	<i>The Consult Room will provide for private consultation and physical examination of patients with or without support persons present. A second egress door may be required for staff safety and security and/or staff access. A hoist, fixed or ceiling mounted (depending on local arrangements) may be required for selected clinical situations. Acoustics: Sound attenuation level - high; Acoustic privacy essential. Body Protected electrical area</i>

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, covered	Default = vinyl: Carpet also acceptable
2526	Floor finish	Vinyl	Non-slip	Seamless covered	Under basin, significant change in colour to be avoided
3000	Wall finish	Paint	Acrylic, washable		
2906	Wall finish			Splashback behind basin	Selection of material to comply with Part D Infection Prevention and Control AusHFG
5007	Ceiling - Plasterboard	Plasterboard	Paint	Bulkhead	Between above bench joinery and ceiling
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
9125	Door - 1400mm	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel	910/1400mm clear opening or a 1200mm clear opening single door. Bariatric provision to be decided at project level
2529	Door protection	Composite	Prefinished PVC	To door frame	
2712	Door protection			Protection plate to 900 AFFL	To be decided at project level
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl covered, 150 mmH	Default = covered skirting : or vinyl featheredge skirting over carpet

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13700	Mirror	1	1	for patient changing
FF-1465	Bracket - suction bottle	2	1	optional
FF-1470	Bracket - sharps	2	1	
FF-150	Air flowmeter	3	1	optional
FF-16250	Oxygen flowmeter	3	1	optional
FF-17360	Pinboard - fabric covered	1	1	over desk, optional
FF-19700	Sharps bin	3	1	Wall mounted

Room Name | Consult Room

Room Number: CONS

AusHFG code	Description	Group	Qty	Comments
FF-20000	Shelving unit - adjustable	1	1	over desk, optional, number to suit layout refer to RLS or project specific requirements.
FF-2100	Chair - ergonomic, office	3	1	
FF-21950	Suction adapter	3	1	optional
FF-22000	Suction bottle	3	1	optional
FF-2600	Chair - visitor, office	3	3	Consider weight capacity of chair
FF-3400	Coathook	1	2	
FF-4600	Curtain track - bed screen	1	1	to exam couch
FF-5000	Curtain - bed screen	3	1	
FF-5900	Desk	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to hand basin
FF-6156	Dispenser - soap	2	1	to hand basin
FF-6158	Dispenser - soap antiseptic	2	1	to hand basin
FF-6153	Dispenser - moisturiser	2	1	
FF-5830	Dispenser - antiseptic hand rub	2	1	
FF-5824	Waste bin - general	3	1	to basin
FF-5824	Waste bin - general	3	1	
FF-21020	Sphygmomanometer - portable	3	0	1 per 6 Consult Rooms. Ratio to be determined at project level.
FF-775	Dispenser - bed roll	2	1	Or provided as an attachment to exam couch

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11400	Computer - PC & monitor	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	High resolution monitor for PACS viewing
FE-15900	Diagnostic set - wall mounted	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-20350	Examination couch - electric	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hi / low operation
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	elbow action levers
FE-31701	Light - examination, wall mount	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Default= wall mounted: or ceiling mounted
FE-41100	Printer - networked	3	0	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	EMR/E-med compatible,

Room Name | Consult Room

Room Number: CONS

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
												printing strategy (centralised vs decentral) to be decided at project level
FE-54520	Telephone - handset, handsfree	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-5836	Xray viewer - 2 screen, portable	3	0	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1 per department, number and location to be decided at project level

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9001	GPO: Double	1	2	
S-9001	GPO: Double	1	1	
S-9011	GPO: Emergency power, double (H)	1	1	for refrigerator
S-9040	Body protected	1	1	
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-10005	Duress alarm	1	1	

Room Name | Consult Room

Room Number: CONS

AusHFG code	Description	Group	Qty	Comments
S-7000	Oxygen (O2)	1	1	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	
S-11000	Wall panel	2	1	patient services panels