

**Room Name** | Corridor - Patient Treatment Areas

**Room Number:** CORR

**Last modified** | 01/03/2016  
**Briefed Area** | 0.00  
**Remarks**  
**Occupancy** | N/A  
**Hours of Operation** |  24 hours  
**Acoustics**  
**Description / Special Requirements**

*Corridor widths must be sized to allow for the safe movement and passing of trolleys, beds, wheelchairs and other mobile equipment. Provisions should also be made where oversized, additional equipment is used, ie, bed extensions or bariatric beds. Area (m<sup>2</sup>) included in HPU circulation. 1 x GPO-Cleaner should be provided as per mandatory requirements. Corridor lighting, where patients are transported on trolleys, positioned to prevent unnecessary glare to patient eyes. Light fittings shall be recessed, flush fitting and sealed to prevent dust ingress. Refer to AusHFG Part C, 710 Space Standards and Dimensions, for further information.*

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Default = vinyl or carpet tiles are also acceptable.
3010	Wall finish	Paint	Scrub resistant		
2670	Wall protection			Corner guards to 900 AFFL minimum	Align heights of corner guards with other corridor elements
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
8040	Door protection	Composite	Prefinished PVC	To door frame	Optional. To be decided at project level.
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	1200mm (single door) or 1500mm (1+1/2 doors) clear opening. Doors widths to ensure movement of trolleys/beds from corridors to adjacent rooms. Glazing optional. Hold open devices may be applied, magnetic hold open devices to fire doors must be connected to the fire alarm system.
7001	Windows				Desirable.
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2729	Handrail				One side minimum. Provision on both sides of corridor to be project specific.
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Default = coved vinyl, featheredged vinyl skirting to carpet tiles.

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-5830	Dispenser - antiseptic hand rub		2	Number to suit corridor layout and Infection Control policies.
FF-5828	External window dressing		3	Number to align with window configuration. Window dressing type

Room Name | Corridor - Patient Treatment Areas

Room Number: CORR

AusHFG code	Description	Group	Qty	Comments
				to comply with Infection Control policy.

## Fixtures, Equipment and associated Services

### Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6001	General: colour corrected	

### Services

AusHFG code	Description	Group	Qty	Comments
S-9015	GPO: Cleaner	1	1	
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-8040	Annunciator	1	1	
S-10020	Card access	1	1	optional; swipe card access