

**Room Name** | CT Scanning - Procedure Room

**Room Number:** CTPR

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	45.00
<b>Remarks</b>	
<b>Occupancy</b>	1 patient; up to 3 staff assisting
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> Available 24 Hours
<b>Acoustics</b>	Acoustic privacy is required
<b>Description / Special Requirements</b>	X-ray Room for CT scanning procedures with an adjacent Control Room and Computer Room. The Control Room may serve more than one CT Scanning Room Acoustics: Acoustic privacy is required Body Protected electrical area Additional Design Considerations: - Radiation shielding as advised by Radiation Consultant - Unistrut ceiling able to carry moving loads may be required - Cable ducts between Control Room and Computer Room may be required - 'X-ray in Use' lights are required outside each entry door - Power should be on emergency supply

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin; tiles also acceptable
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL	Equal to 'Acrovyn'
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	at 3000 mm AFFL
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to 'Acrovyn'
9130	Door - 1600mm	Solid Core	Paint	1 1/2 leaf, with lead shielding	patient entry/ exit 1500mm clear opening
7025	Observation	Lead glass	Clear	Internal window	to control room
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1465	Bracket - suction bottle		2	
FF-150	Air flowmeter		3	1
FF-16250	Oxygen flowmeter		3	2
FF-21950	Suction adapter		3	2
FF-22000	Suction bottle		3	2
FF-6152	Dispenser - disposable glove		2	1 near door
FF-6154	Dispenser - paper/ hand towel		2	1 to basin
FF-6156	Dispenser - soap		2	1 to basin
FF-6158	Dispenser - soap antiseptic		2	1 to basin
FF-5824	Waste bin - general		3	1 to basin

Room Name | CT Scanning - Procedure Room

Room Number: CTPR

AusHFG code	Description	Group	Qty	Comments
FF-111670	Cupboard - with glazed doors	3	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-3100	Basin - scrub, Type A	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-A (sim)
FE-66500	IMG - CT Scanning unit	1	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-68700	Xray viewer - 2 screen	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-9700	Clock - analogue, electric	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6110	Downlights: dimmable	optional
S-12030	Lead lining	to walls and doors as specified

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	6	monitor
S-9001650	GPO: Double RCD		2	Imported 150916
S-9015	GPO: Cleaner	1	1	
S-9011	GPO: Emergency power, double (H)	1	2	for refrigerator
S-9040	Body protected	1	1	
S-9060	GPO: Special: for equipment	1	1	TV, ceiling
S-1005	Voice / Data outlet: single	1	1	in ceiling for data projector; optional
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-1040	Intercom	1	1	optional
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	2	
S-6110	Downlights: dimmable	1	1	optional

**Room Name | CT Scanning - Procedure Room**
**Room Number: CTPR**

AusHFG code	Description	Group	Qty	Comments
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	2	
S-7010	Nitrous Oxide (N2O)	1	1	services panel
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	2	
S-7070	Scavenge	1	1	services panel
S-11000	Wall panel	2	3	patient services panels
S-12030	Lead lining	1	1	to walls and doors as specified