

**Room Name** | Dining - Patients

**Room Number:** DINR

**Last modified** 01/03/2016

**Briefed Area** 72.00

**Remarks**

**Occupancy** 24 patients seated, 1-2 staff intermittently

**Hours of Operation** ☒ 24 Hours

**Acoustics**

**Description / Special Requirements**

*The Dining Room is an area provided for patients to eat their meals away from the bedroom environment in an inpatient setting. The Dining Room may be used for other patient recreational activities when not in use for meals. In this instance attention to sound separation must be considered. Size of space will depend on number of beds and Models of Care, designed area based on 3m2 per person. Access and dining space will be required for patients with limited mobility including wheelchairs, walking frames and other walking aids. Design must also consider the needs of dementia patients and frail/elderly. Special design consideration:- Natural light and outlook essential.- Domestic appearance.- Constant lighting across space.- Beverage Bay and/or an ADL Kitchen may be collocated depending on Model of Care requirements. Acoustics: sound attenuation level-high; acoustic privacy is required.*

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Significant change in colour to be avoided
3000	Wall finish	Paint	Acrylic, washable		
2670	Wall protection			Corner guards to 900 AFFL minimum	
2727	Wall finish			Splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG.
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
8040	Door protection	Composite	Prefinished PVC	To door frame	Optional. To be decided at project level
9128	Door - 1200mm	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel	1200mm (single door) or 1400mm (1+1/2 doors) clear opening. Glazing optional, lockable.
7001	Windows				Essential
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1700	Chair - dining	3	24	
FF-23000	Table - dining	3	6	
FF-23410	Bracket - television, wall mount	1	1	Optional
FF-5830	Dispenser - antiseptic hand rub	2	1	
FF-5824	Waste bin - general	3	1	
FF-5828	External window dressing	3	3	To external window as required. Number to suit window configuration.

Room Name | Dining - Patients

Room Number: DINR

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-54520	Telephone - handset, handsfree (WM)	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-2795	Television	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Optional
FE-18610	DVD player	3	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Optional. May be replaced by newer technology.

## Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6030	Special: downlights	over bed/ trolley

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9001	GPO: Double	1	3	
S-9040	Body protected	1	1	
S-1005	Voice / Data outlet: single	1	1	in ceiling for data projector; optional
S-1090	TV: MATV	1	1	
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	2	
S-6030	Special: downlights	1	1	over bed/ trolley
S-8000	Patient/ Staff call	1	3	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	2	+ indicator button & light