

**Room Name** | Disposal Room, 10m2

**Room Number:** DISP-10

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	10.00
<b>Remarks</b>	
<b>Occupancy</b>	
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	
<b>Description / Special Requirements</b>	<i>The Disposal Room provides for the temporary holding of clinical waste, general waste, sharps, soiled linen and recyclables prior to removal. The Disposal Room should be located in close proximity to a handwashing basin or be provided within the room (optional) if waste will be handled in this area. The room should be lockable.</i>

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2593	Wall protection			Wall vinyl full height	
5030	Ceiling - Plasterboard	Plasterboard	Prefinished	Drop-in tiles, 600x1200	
2529	Door protection	Composite	Prefinished PVC	To door frame	
2712	Door protection			Protection plate to 900 AFFL	
2718	Doors	Solid Core	Paint	Single leaf	Optional glazed viewing panel to door
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-23925	Trolley - soiled linen collection	3	1	
FF-24102	Waste bin - general	3	2	240 Litre
FF-24125	Waste bin - clinical	3	2	240 Litre or waste skip
FF-6152	Dispenser - disposable glove	2	1	
FF-5830	Dispenser - antiseptic hand rub	2	1	
FF-24107	Waste bin - cytotoxic	3	1	

## Fixtures, Equipment and associated Services

### Service Requirements

AusHFG code	Description	Comments
S-5015	Ventilation	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

### Services

Room Name | Disposal Room, 10m2

Room Number: DISP-10

AusHFG code	Description	Group	Qty	Comments
S-5015	Ventilation	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	