

**Room Name** | Echocardiography - Trans-oesophageal

**Room Number:** ECHO

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	30.00
<b>Remarks</b>	
<b>Occupancy</b>	1 patient; 1 - 2 staff
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> Available 24 Hours
<b>Acoustics</b>	Acoustic privacy is required
<b>Description or Special Requirements</b>	Room for diagnostic echocardiography procedures including trans-oesophageal echocardiography. Echocardiography procedures may be performed under local anaesthesia. The Echocardiography room should be located close to patient toilet and change rooms. Acoustics: Acoustic privacy requiredBody Protected electrical area

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin; tiles also acceptable
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9110	Door - 1400mm	Solid Core	Paint	1 1/2 leaf	1400mm clear opening
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	
FF-150	Air flowmeter	3	1	patient services panel
FF-16250	Oxygen flowmeter	3	1	patient services panel
FF-1650	Chair - client	3	1	
FF-2100	Chair - ergonomic, office	3	1	
FF-21950	Suction adapter	3	1	patient services panel
FF-3350	Clock - battery operated	3	1	
FF-3400	Coathook	1	1	
FF-4360	Cupboard - door ht adj. shelves	1	1	
FF-4410	Cupboard - under bench	1	1	adjustable shelves
FF-4460	Cupboard - wall mounted	1	1	over bench
FF-4700	Curtain track - privacy screen (90 deg)	1	1	to entry door
FF-5250	Curtain - privacy screen	3	1	to entry door

**Room Name | Echocardiography - Trans-oesophageal**
**Room Number: ECHO**

AusHFG code	Description	Group	Qty	Comments
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-7500	Examination couch	3	1	
FF-8100	Footstool	3	1	
FF-44716	Overbench double door lockable (600hx800wx350d)	1	1	
FF-5824	Waste bin - general	3	1	to basin

### Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-19200	IMG - Echocardiography machine	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-54520	Telephone - handset, handsfree (WM)	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-68700	Xray viewer - 2 screen	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional
FE-5857	Light - procedures small, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional

### Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6110	Downlights: dimmable	optional

### Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	3	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	4	monitor
S-9001	GPO: Double	1	4	
S-9040	Body protected	1	1	
S-9060	GPO: Special: for equipment	1	3	TV, ceiling
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-5000	Airconditioning	1	1	

Room Name | Echocardiography - Trans-oesophageal

Room Number: ECHO

AusHFG code	Description	Group	Qty	Comments
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	3	
S-6055	Special: task light, built in	1	2	under O/H cupboards
S-6110	Downlights: dimmable	1	1	optional
S-8000	Patient/ Staff call	1	2	+ indicator button & light
S-8005	Patient call handset	1	2	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	2	+ indicator button & light
S-7000	Oxygen (O2)	1	1	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	
S-11000	Wall panel	2	1	patient services panels