

Room Name | **Equipment Clean-Up/Loan Equipment, 12m2** | **Room Number: ECL-12**

Last modified	01/03/2016
Briefed Area	12.00
Remarks	
Occupancy	1 - 2 staff intermittently
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	
Description / Special Requirements	<i>The Equipment Clean Up Room is used for cleaning of equipment used in patient care or loaned to outpatients following return. Storage will be required for holding cleaning equipment.</i>

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
2526	Floor finish	Vinyl	Non-slip	Seamless coved	
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL	
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	Water resistant flush set suspended also acceptable.
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
8040	Door protection	Composite	Prefinished PVC	To door frame	Optional. To be decided at project level.
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	1100mm clear opening, lockable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1010	Bench - stainless steel	1	1	with wet edge and inset sink/s. Length to suit layout, refer RLS or project specific requirements.
FF-19820	Shelf - SS, under	1	1	At 350mm AFFL or underbench, stainless steel cupboard.
FF-20000	Shelving unit - adjustable	1	2	Over bench. Number to suit layout, refer RLS or project specific requirements.
FF-4360	Cupboard - door ht adj. shelves	1	1	Lockable, optional. Number to suit layout.
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-7515	Platform - equipment washing	3	1	Stainless steel, grated, height adjustable, wall mounted.

Room Name | Equipment Clean-Up/Loan Equipment, 12m2

Room Number: ECL-12

AusHFG code	Description	Group	Qty	Comments
FF-6214	Trolley - equipment	3	1	Optional.
FF-6153	Dispenser - moisturiser	2	0	Optional
FF-5830	Dispenser - antiseptic hand rub	2	1	Optional
FF-5824	Waste bin - general	3	1	
FF-24405	Whiteboard - magnetic	2	1	
FF-6150	Dispenser - detergent	2	1	To sink.
FF-2930	Dispenser - gown	2	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Elbow action levers or handsfree optional.
FE-45600	Hose reel - retractable	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-49000	Sink - 500x450x250D	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	hot water
FE-5597	Hose spray - pressure control	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Above sink, optional. Depends on operational/ infection control policies.

Service Requirements

AusHFG code	Description	Comments
S-5015	Ventilation	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	1	
S-4000	Hot water: outlet	1	2	to washing machine
S-4010	Cold water: outlet	1	2	to washing machine
S-4033	Floor waste	1	1	
S-5015	Ventilation	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	

Room Name

| Equipment Clean-Up/Loan Equipment, 12m2

Room Number: ECL-12
