

**Room Name** | Equipment Clean-Up, 8m2

**Room Number:** ECL-8

**Last modified** | 01/03/2016  
**Briefed Area** | 8.00  
**Remarks**  
**Occupancy** | 1 - 2  
**Hours of Operation** |  24 Hours  
**Acoustics**  
**Description or Special Requirements**

*The Equipment Clean-Up Room is used for cleaning and maintaining of equipment used in the Unit. Storage may be required for holding cleaned equipment and spares. Equipment may also be recharged in this room. Natural light is desirable.*

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL	
5021	Ceiling - Plasterboard	Plasterboard	Paint, washable	Water resistant, flush set, suspended	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to 'Acrovyn'
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	1100mm clear opening, lockable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1010	Bench - stainless steel	1	1	with wet edge, inset sink
FF-19820	Shelf - SS, under	1	1	under bench
FF-20000	Shelving unit - adjustable	1	1	over bench
FF-4360	Cupboard - door ht adj. shelves	1	1	lockable, optional
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	
FF-5824	Waste bin - general	3	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Refer to BHWS-B (sim)

**Room Name** | Equipment Clean-Up, 8m2

**Room Number:** ECL-8

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-49000	Sink - 500x450x250D	1	2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	hot water
FE-4045	Tapware - elbow mixer		2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

### Service Requirements

AusHFG code	Description	Comments
S-5015	Ventilation	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

### Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double		2	
S-4033	Floor waste		1	
S-5015	Ventilation		1	
S-5019	Exhaust		1	to rangehood
S-6000	General fluorescent		1	
S-6200	Light switches		1	