

Room Name | **Ensuite - Bariatric**

Room Number: ENS-BA

Last modified	01/03/2016
Briefed Area	7.00
Remarks	
Occupancy	1 patient; 1-2 staff assisting
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	Sound attenuation level high, Acoustic privacy is required.
Description / Special Requirements	An Ensuite - Bariatric is designed to meet the needs of bariatric (obese or morbidly obese) patients allowing the patient to wash, shave, groom themselves, shower and use the toilet, either independently or with assistance. The Ensuite - Bariatric is associated with the 1 Bed Room - Bariatric. The area and layout must accommodate two assisting nurses and a shower commode with bariatric capability. The Ensuite and Bedroom will need to be planned as an integral suite so the use of a ceiling mounted hoist is optimised across the two rooms. The choice of Ensuite will depend on the patient type, the Operational Policy and floor layout of the facility. Acoustics: Sound attenuation level - High. Acoustic privacy required. Body protected electrical area. Additional Design Requirements: - The shower floor must not have a raised hob - The entrance is to be flush with the adjoining flooring - The door is to be fitted with escape hardware

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
3000	Wall finish	Paint	Acrylic, washable		
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to wet areas; tiles also acceptable
2525	Wall protection			Bed protection wall panel	
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
9110	Door - 1400mm	Solid Core	Paint	1 1/2 leaf	1200mm clear opening, outward opening, privacy latch, emergency release
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
2529	Door protection	Composite	Prefinished PVC	To door frame	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	or tiles for a tiled floor

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13700	Mirror	1	1	over basin
FF-19100	Waste bin - sanitary	3	1	
FF-20603	Soap / shampoo holder - recessed	1	1	
FF-23700	Towel rail	1	1	
FF-3400	Coathook	1	2	1 @ 1200 AFFL for wheelchair users
FF-4800	Curtain track - shower (90deg)	1	1	
FF-5300	Curtain - shower	3	1	
FF-6154	Dispenser - paper/ hand towel	2	1	optional
FF-6156	Dispenser - soap	2	2	optional

Room Name | Ensuite - Bariatric

Room Number: ENS-BA

AusHFG code	Description	Group	Qty	Comments
FF-6160	Dispenser - toilet paper	1	1	
FF-8450	Grab rail - Shower	1	1	
FF-8500	Grab rail - WC, hinged	1	2	optional
FF-5673	Chair - shower, bariatric	3	1	
FF-5824	Waste bin - general	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-47400	Shower - hand-held	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-5603	Basin - ensuite	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-5602	Toilet suite - bariatric	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FF-39155	Patient lifter, ceiling mounted	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-40406	Tapware - shower mixer	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5015	Ventilation	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	1	
S-4033	Floor waste	1	2	
S-5015	Ventilation	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	2	+ indicator button & light
S-8070	Patient call pendant	1	1	waterproof, for bath
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light

Room Name | **Ensuite - Bariatric**Room Number: **ENS-BA**

AusHFG code	Description	Group	Qty	Comments
S-7000	Oxygen (O2)	1	1	