

Room Name | **Gymnasium, 60m2**

Room Number: GYAH-60

Last modified	01/03/2016
Briefed Area	60.00
Remarks	
Occupancy	Up to 13 patients/ hour; up to 4 staff
Hours of Operation	<input checked="" type="checkbox"/> 8am to 6pm daily
Acoustics	Acoustic privacy is required
Description or Special Requirements	The Gymnasium provides for patient evaluation, rehabilitation exercise activities, therapy and ambulation training. An external outlook is desirable. The equipment to be used in this area will be dependent on the function of the gym and the Operational Policy. Acoustics: Acoustic privacy required. Body Protected electrical area

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin & sink, tiles also acceptable
5030	Ceiling - Plasterboard	Plasterboard	Prefinished	Drop-in tiles, 600x1200	flush set plasterboard ceiling also acceptable
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to 'Acrovyn'
9225	Door - 1500mm	Solid Core/ Glass	Paint	Double leaf, observation panel	1400 mm clear opening, lockable
7001	Windows				desirable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	cushioned vinyl optional

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate		1	optional
FF-12450	Locker - bedside		3	2 or trolley, to plinth spaces
FF-1250	Blind - Venetian		3	3 1 to each external/ internal window, if provided
FF-1325	Mirror - safety glass		1	2
FF-13645	Steel mesh - framed, ceiling mount		1	2 to plinths, optional
FF-13646	Steel mesh - framed, wall mount		1	2 to plinths, optional
FF-1650	Chair - client		3	2
FF-16780	Parallel bars		3	1 min 5 metres long
FF-17630	Plinth		3	2
FF-18170	Pulley weights - wall mounted		3	1 optional
FF-3350	Clock - battery operated		3	1

Room Name | Gymnasium, 60m2

Room Number: GYAH-60

AusHFG code	Description	Group	Qty	Comments
FF-4410	Cupboard - under bench	1	2	optional
FF-4430	Cupboard - drawer unit	1	1	under bench, optional
FF-4460	Cupboard - wall mounted	1	2	over bench, optional
FF-4600	Curtain track - bed screen	1	2	to plinth spaces
FF-5000	Curtain - bed screen	3	2	to plinth spaces
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	2	to basin & sink
FF-6156	Dispenser - soap	2	2	to basin & sink
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-7520	Exercise bicycle	3	2	optional
FF-7530	Exercise stairs	3	1	optional
FF-5824	Waste bin - general	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS (sim)
FE-47890	Sink & drainer - single, 930mmL	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	optional, hot water
FE-54520	Telephone - handset, handsfree (WM)	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-4045	Tapware - elbow mixer		1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	9	
S-9015	GPO: Cleaner	1	1	
S-9040	Body protected	1	1	
S-1000	Telephone: PABX	1	1	wall telephone
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone

Room Name | Gymnasium, 60m2

Room Number: GYAH-60

AusHFG code	Description	Group	Qty	Comments
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	2	+ indicator button & light
S-8005	Patient call handset	1	2	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	3	+ indicator button & light