

Room Name | Mammography

Room Number: MAMMO

Last modified	01/03/2016
Briefed Area	16.00
Remarks	
Occupancy	1 patient; Up to 2 staff assisting
Hours of Operation	<input checked="" type="checkbox"/> Available 24 Hours
Acoustics	Acoustic privacy is required
Description / Special Requirements	X-ray room for mammography imaging procedures, with change area within the room. Acoustics: Acoustic privacy required Body Protected electrical area Additional Design Considerations: - Radiation shielding as advised by Radiation Consultant - Cable ducts between X-ray table and control area may be required - 'X-ray in Use' lights required outside each entry door

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9130	Door - 1600mm	Solid Core	Paint	1 1/2 leaf, with lead shielding	1400mm clear opening
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13700	Mirror	1	1	to change area
FF-1650	Chair - client	3	1	to change area
FF-20000	Shelving unit - adjustable	1	1	above desk, optional
FF-2055	Chair - mammography	3	1	'Hausted'
FF-2100	Chair - ergonomic, office	3	1	to desk
FF-3400	Coathook	1	2	to change area, 1 @ 1200H
FF-4700	Curtain track - privacy screen (90 deg)	1	1	to change area
FF-5250	Curtain - privacy screen	3	1	to change area
FF-5900	Desk	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin

Room Name | Mammography

Room Number: MAMMO

AusHFG code	Description	Group	Qty	Comments
FF-5824	Waste bin - general		3	1 to basin
FF-43503	Full height cupboard (2100hx900wx350d)		1	1 adjustable shelves

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-B (sim)
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to desk
FE-66700	IMG - Mammography imaging unit	1	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	with control panel
FE-68700	Xray viewer - 2 screen	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	above desk

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6110	Downlights: dimmable	optional
S-12030	Lead lining	to walls and doors as specified

Services

AusHFG code	Description	Group	Qty	Comments
S-9010	GPO: Emergency power, single (H)		1	2 monitor
S-9001	GPO: Double		1	3
S-9015	GPO: Cleaner		1	1
S-9040	Body protected		1	1
S-9050	Direct connection		3	1 XRV, clocks, lights
S-9060	GPO: Special: for equipment		1	1 TV, ceiling
S-1006	Voice / Data outlet: double		1	1 outlet for telephone
S-5000	Airconditioning		1	1
S-6001	General: colour corrected		1	1
S-6200	Light switches		1	3
S-6110	Downlights: dimmable		1	1 optional
S-8010	Staff/ Nurse assist call		1	1 + indicator button & light
S-8080	Emergency call		1	1 + indicator button & light
S-1951	Staff assist call		1	1 + indicator button & light

Room Name | Mammography

Room Number: MAMMO

AusHFG code	Description	Group	Qty	Comments
S-12030	Lead lining	1	1	to walls and doors as specified