

**Room Name** | Mortuary - Autopsy Room

**Room Number:** MOR-AU

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	30.00
<b>Remarks</b>	
<b>Occupancy</b>	Up to 4
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> Available 24 Hours
<b>Acoustics</b>	
<b>Description or Special Requirements</b>	Room for undertaking post mortem examinations. The Autopsy Room should be located adjacent to the Body Cool Store and have ready access to a clean-up area. Additional Design Considerations - Doors to be sealed for odours - Post mortem table to have water flushing system - An observation area is optional

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to 'Acrovyn'
9128	Door - 1200mm	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel	1400mm clear opening
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height	observation window/s
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1010	Bench - stainless steel		1	with wet edge & draining sink
FF-1470	Bracket - sharps		2	
FF-1550	Cabinet - instrument		3	
FF-19700	Sharps bin		3	
FF-19820	Shelf - SS, under		1	3 under SS bench
FF-21730	Stool - operating, mobile		3	
FF-21950	Suction adapter		3	1 to table
FF-23950	Trolley		3	
FF-24125	Waste bin - clinical		3	
FF-3350	Clock - battery operated		3	
FF-6152	Dispenser - disposable glove		2	
FF-6154	Dispenser - paper/ hand towel		2	1 to basin

Room Name | Mortuary - Autopsy Room

Room Number: MOR-AU

AusHFG code	Description	Group	Qty	Comments
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-5824	Waste bin - general	3	1	
FF-24405	Whiteboard - magnetic	2	1	900x900, optional

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-3100	Basin - scrub, Type A	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-A (sim); sensor taps
FE-45600	Hose reel - retractable	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-49000	Sink - 500x450x250D	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	sensor taps, hot water
FE-49205	Sink - draining	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	in bench, sensor taps, hot water
FE-53050	Saw - surgical	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-54100	Table - post mortem	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	& medical gases to pedestal
FE-54520	Telephone - handset, handsfree	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	wall telephone
FE-68700	Xray viewer - 2 screen	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	recessed
FE-5857	Light - procedures small, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-40404	Tapware - sensor	1	2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-5019	Exhaust	to rangehood
S-6001	General: colour corrected	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	5	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	2	monitor
S-9001	GPO: Double	1	1	
S-1000	Telephone: PABX	1	1	wall telephone

Room Name | Mortuary - Autopsy Room

Room Number: MOR-AU

AusHFG code	Description	Group	Qty	Comments
S-1040	Intercom	1	1	optional
S-4030	Drainage	1	2	to contaminated water trap
S-4033	Floor waste	1	2	
S-5000	Airconditioning	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	1	
S-7030	Tool Air	1	1	to table
S-7040	Suction	1	1	