

Room Name | Neonatal Bay - Special Care

Room Number: NBSC

Last modified	01/03/2016
Briefed Area	10.00
Remarks	
Occupancy	1 baby; 1-2 staff; 1-2 parents
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	Sound attenuation level high, Acoustic privacy is required to perimeter walls.
Description or Special Requirements	A single bay for neonates requiring Special Care nursing and medical treatment. The Bay will include provisions for charting and storage. A staff handwash basin (Type A) should be provided within close access of each Bay. An external outlook is required. Acoustics: Sound attenuation level - high; Acoustic privacy is required to perimeter walls Cardiac Protected electrical area

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
7001	Windows				External outlook to the area is required
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	
FF-1465	Bracket - suction bottle	2	2	
FF-150	Air flowmeter	3	2	
FF-16250	Oxygen flowmeter	3	2	
FF-20000	Shelving unit - adjustable	1	3	over bench
FF-21950	Suction adapter	3	2	
FF-22000	Suction bottle	3	1	
FF-2655	Chair - visitor	3	2	
FF-4410	Cupboard - under bench	1	2	
FF-4430	Cupboard - drawer unit	1	2	under bench
FF-4600	Curtain track - bed screen	1	1	
FF-5000	Curtain - bed screen	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-26000	Humidicrib	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	or bassinette

Room Name | Neonatal Bay - Special Care

Room Number: NBSC

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-5857	Light - procedures small, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9030	Cardiac protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6005	Dimmable	for image viewing
S-6055	Special: task light, built in	under O/H cupboards

Services

AusHFG code	Description	Group	Qty	Comments
S-9010	GPO: Emergency power, single (V)		1	8 monitor
S-9015	GPO: Cleaner		1	1
S-9030	Cardiac protected		1	1
S-9060	GPO: Special: for equipment		1	1 TV, ceiling
S-1006	Voice / Data outlet: double		1	1 outlet for telephone
S-5000	Airconditioning		1	1
S-6001	General: colour corrected		1	1
S-6005	Dimmable		1	1 for image viewing
S-6200	Light switches		1	1
S-6055	Special: task light, built in		1	3 under O/H cupboards
S-8010	Staff/ Nurse assist call		1	1 + indicator button & light
S-8080	Emergency call		1	1 + indicator button & light
S-1951	Staff assist call		1	1 + indicator button & light
S-7000	Oxygen (O2)		1	2
S-7020	Medical Air (MA)		1	2
S-7040	Suction		1	2
S-11000	Wall panel		2	1 patient services panels