

Room Name | Parenting Room

Room Number: PAR

Last modified	01/03/2016
Briefed Area	6.00
Remarks	
Occupancy	Up to 2
Hours of Operation	<input checked="" type="checkbox"/> Available 24 Hours
Acoustics	Sound attenuation level high, Acoustic privacy is required.
Description / Special Requirements	The Parenting Room is provided for parents to feed and change babies, and will provide access for prams. The Parenting Room will be located with other child related facilities and have ready access to a Toilet and Waiting area. Acoustics: Sound attenuation level - High. Acoustic privacy required.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	tiles also acceptable
3000	Wall finish	Paint	Acrylic, washable		
2727	Wall finish			Splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG.
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
9001	Door - 1100mm	Solid Core	Paint	Single leaf	910mm clear opening, privacy latch
2529	Door protection	Composite	Prefinished PVC	To door frame	To be decided at project level.
2712	Door protection			Protection plate to 900 AFFL	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	or tiles for tiled floor

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	with sink. Length to suit layout, refer RLS or project specific requirements.
FF-2000	Chair - lounge	3	1	
FF-3400	Coathook	1	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to sink
FF-6156	Dispenser - soap	2	1	to sink
FF-7229	Baby change mat	1	1	
FF-5860	Waste bin - fliptop	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-47800	Sink, SS - single in bench	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	warm water. Tapware: sink mixer, fixture mounted.

Room Name | Parenting Room

Room Number: PAR

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-40403	Tapware - accessible basin mixer	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double		1	
S-5000	Airconditioning		1	
S-5019	Exhaust		1	to rangehood
S-6000	General fluorescent		1	
S-6200	Light switches		1	