

Room Name | Patient Bay - Critical, 24m2

Room Number: PBC-24

Last modified	01/03/2016
Briefed Area	24.00
Remarks	
Occupancy	1 patient, 1-2 visitors, Up to 6-8 staff
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	Acoustic privacy is required
Description or Special Requirements	A Single Bed Bay for patient requiring critical care nursing and medical treatment; Visual access to Staff Station is required; Screen curtains are required for patient privacy. Maximum natural light is required to patient beds. Acoustics: Acoustic privacy is required. Cardiac Protected Electrical Area

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin, tiles also acceptable
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL	Equal to 'Acrovyn'
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
7001	Windows				desirable
7055	Observation	Alum/ Glass	Powdercoat	Internal window, double glazed	to partition walls, with integral Venetians
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-12300	Linen carrier - dirty, single	3	1	
FF-1252	Blind - Venetian integral	1	3	to windows, controls to both sides
FF-1470	Bracket - sharps	2	1	mounted to trolley
FF-150	Air flowmeter	3	2	
FF-16200	Table - overbed	3	1	
FF-16250	Oxygen flowmeter	3	4	
FF-19700	Sharps bin	3	1	on trolley
FF-21700	Stool - adjustable, mobile, high	3	1	for staff
FF-21950	Suction adapter	3	4	
FF-2200	Chair - recliner	3	1	patient - intermittent use
FF-22000	Suction bottle	3	4	
FF-22050	Suction bottle carrier	3	1	mobile
FF-23950	Trolley	3	1	

Room Name | Patient Bay - Critical, 24m2

Room Number: PBC-24

AusHFG code	Description	Group	Qty	Comments
FF-24400	Whiteboard		2	1 600mm x 600mm
FF-2610	Chair - visitor, stackable		3	1
FF-4600	Curtain track - bed screen		1	1
FF-6152	Dispenser - disposable glove		2	1
FF-6154	Dispenser - paper/ hand towel		2	1 to basin
FF-6156	Dispenser - soap		2	1 to basin
FF-6158	Dispenser - soap antiseptic		2	1 to basin
FF-8070	Flowchart stand - mobile		3	1
FF-5825	Bracket - patient entertainment, ceiling		1	1
FF-5824	Waste bin - general		3	1
FF-5975	Waste bin - clinical		3	1
FF-5591	Bracket - cardiac monitor		3	1 mounted on pendant

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-15985	Dialysis station	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	with RO water & tundish drain
FE-3100	Basin - scrub, Type A	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-A (sim)
FE-31700	Light - examination, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-36050	Monitor - cardiac	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-54520	Telephone - handset, handsfree	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to staff work area
FE-9700	Clock - analogue, electric	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	ceiling mounted, master clock system
FF-5547	Patient entertainment	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-5854	Bed - ICU, electric + patient mattress	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-5859	Services pendant - 2 arm	1	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9030	Cardiac protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	

Room Name | Patient Bay - Critical, 24m2

Room Number: PBC-24

AusHFG code	Description	Comments
S-6060	Special: night lights	

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	12	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	12	monitor
S-9001	GPO: Double	1	2	
S-9001	GPO: Double	1	2	
S-9015	GPO: Cleaner	1	1	
S-9030	Cardiac protected	1	1	
S-9011	GPO: Emergency power, double (H)	1	1	for refrigerator
S-9060	GPO: Special: for equipment	1	3	TV, ceiling
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-1090	TV: MATV	1	1	
S-1120	Monitor connection facilities and cabling	1	1	optional
S-4037	Tundish drain	1	1	for low temp steriliser, optional
S-4045	Reverse osmosis (RO) water outlet	1	1	
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6060	Special: night lights	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	4	
S-7020	Medical Air (MA)	1	2	
S-7040	Suction	1	4	
S-11050	Column	1	1	for power/ data, ceiling suspended