

**Room Name** | Patient Bay - Acute Treatment, 12m2

**Room Number:** PBTR-A12

|  |   |
|--|---|
| <b>Last modified</b>                       | 01/03/2016  |
| <b>Briefed Area</b>                        | 12.00   |
| <b>Remarks</b>                             |   |
| <b>Occupancy</b>                           | 1 patient; 1 - 2 staff  |
| <b>Hours of Operation</b>                  | <input checked="" type="checkbox"/> 24 Hours  |
| <b>Acoustics</b>                           |   |
| <b>Description or Special Requirements</b> | <i>The Patient Bed Bay Acute Treatment may be used for assessment and treatment of patients with acute conditions and will be located within the Emergency Unit. The Bay may have partition side walls; glazing is recommended. The Patient Bay will have close access to a staff handwashing basin. Body Protected electrical area</i> |

## Room Fabrics

| AusHFG code | Description            | Material     | Finish                  | Specification                  | Comments                        |
|-------------|------------------------|--------------|-------------------------|--------------------------------|---------------------------------|
| 1000        | Floor finish           | Vinyl        | Standard slip resistant | Seamless, coved                |                                 |
| 3000        | Wall finish            | Paint        | Acrylic, washable       |                                |                                 |
| 3092        | Wall protection        | MDF          | Laminate                | Bed protection wall panel      |                                 |
| 4020        | Wall protection        | Composite    | Prefinished PVC         | Crash rail at 900 AFFL         | As required, Equal to 'Acrovyn' |
| 4031        | Wall protection        | Composite    | Prefinished PVC         | Corner guards to 1500 AFFL     | As required, Equal to 'Acrovyn' |
| 5010        | Ceiling - Plasterboard | Plasterboard | Paint, washable         | Flush set, suspended           |                                 |
| 7055        | Observation            | Alum/ Glass  | Powdercoat              | Internal window, double glazed | to partition walls, if provided |
| 6030        | Cornice                | Aluminium    | Powdercoat              | 24mm shadow angle              |                                 |
| 2000        | Skirting               | Vinyl        | Prefinished             | Floor vinyl coved, 150 mmH     |                                 |

## Fittings and Furniture

| AusHFG code | Description                     | Group | Qty | Comments                         |
|-------------|---------------------------------|-------|-----|----------------------------------|
| FF-10200    | Trolley - instrument            | 3     | 1   |                                  |
| FF-10700    | IV hanger for ceiling track     | 1     | 1   |                                  |
| FF-1090     | Bench - laminate, free standing | 1     | 1   | optional                         |
| FF-11200    | IV track - ceiling mounted      | 1     | 1   |                                  |
| FF-1252     | Blind - Venetian integral       | 1     | 2   | to internal windows if provided  |
| FF-12900    | Wire panel - for storage-bins   | 1     | 1   | optional, for storage            |
| FF-1465     | Bracket - suction bottle        | 2     | 1   |                                  |
| FF-1470     | Bracket - sharps                | 2     | 1   |                                  |
| FF-150      | Air flowmeter                   | 3     | 1   |                                  |
| FF-15100    | Bracket - monitor               | 3     | 1   | optional, may have ergonomic arm |
| FF-16250    | Oxygen flowmeter                | 3     | 2   |                                  |
| FF-19700    | Sharps bin                      | 3     | 1   |                                  |

Room Name | Patient Bay - Acute Treatment, 12m2

Room Number: PBTR-A12

| AusHFG code | Description                  | Group | Qty | Comments                               |
|-------------|------------------------------|-------|-----|--|
| FF-19800    | Shelf - laminate             | 1     | 1   | above services panel, optional         |
| FF-21755    | Storage bins                 | 3     | 10  | optional, for storage on louvred panel |
| FF-21950    | Suction adapter              | 3     | 2   |  |
| FF-22000    | Suction bottle               | 3     | 1   |  |
| FF-23952    | Trolley - small              | 3     | 1   |  |
| FF-2650     | Chair - visitor, patient     | 3     | 1   |  |
| FF-4600     | Curtain track - bed screen   | 1     | 1   |  |
| FF-5000     | Curtain - bed screen         | 3     | 1   |  |
| FF-6152     | Dispenser - disposable glove | 2     | 1   |  |

## Fixtures, Equipment and associated Services

| AusHFG code | Description                            | Grp | Qty | Ele                                 | Data                                | CdW                      | HtW                      | WmW                      | Tap                      | Dns                      | Gas                      | Comments |
|-------------|--|-----|-----|-------------------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|----------|
| FE-15900    | Diagnostic set - wall mounted          | 3   | 1   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | optional |
| FE-36055    | Monitor - cardiac with vital signs     | 3   | 1   | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | optional |
| FE-5854     | Bed - ICU, electric + patient mattress | 3   | 1   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |          |
| FE-5857     | Light - procedures small, ceiling      | 1   | 1   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |          |

## Service Requirements

| AusHFG code | Description               | Comments |
|-------------|---------------------------|----------|
| S-9040      | Body protected            |          |
| S-5000      | Airconditioning           |          |
| S-6001      | General: colour corrected |          |

## Services

| AusHFG code | Description                      | Group | Qty | Comments                            |
|-------------|----------------------------------|-------|-----|-------------------------------------|
| S-9000      | GPO: Single                      | 1     | 1   | Bedhead low level, for electric bed |
| S-9000      | GPO: Single                      | 1     | 4   | Bedhead low level, for electric bed |
| S-9010      | GPO: Emergency power, single (V) | 1     | 4   | monitor                             |
| S-9040      | Body protected                   | 1     | 1   |                                     |
| S-9060      | GPO: Special: for equipment      | 1     | 1   | TV, ceiling                         |
| S-1006      | Voice / Data outlet: double      | 1     | 1   | 1 outlet for telephone              |
| S-1090      | TV: MATV                         | 1     | 1   |                                     |

Room Name | Patient Bay - Acute Treatment, 12m2

Room Number: PBTR-A12

| AusHFG code | Description                               | Group | Qty | Comments                                  |
|-------------|---|-------|-----|---|
| S-1120      | Monitor connection facilities and cabling | 1     | 1   | optional                                  |
| S-5000      | Airconditioning                           | 1     | 1   |   |
| S-6001      | General: colour corrected                 | 1     | 1   |   |
| S-6200      | Light switches                            | 1     | 1   |   |
| S-8000      | Patient/ Staff call                       | 1     | 1   | + indicator button & light                |
| S-8005      | Patient call handset                      | 1     | 1   | call button & light switch on the handset |
| S-8010      | Staff/ Nurse assist call                  | 1     | 1   | + indicator button & light                |
| S-8080      | Emergency call                            | 1     | 1   | + indicator button & light                |
| S-1951      | Staff assist call                         | 1     | 1   | + indicator button & light                |
| S-2072      | Scavenge Outlet                           | 1     | 1   | and controls, on wall, optional           |
| S-7000      | Oxygen (O2)                               | 1     | 2   |   |
| S-7010      | Nitrous Oxide (N2O)                       | 1     | 1   | services panel                            |
| S-7020      | Medical Air (MA)                          | 1     | 1   |   |
| S-7040      | Suction                                   | 1     | 2   |   |
| S-7070      | Scavenge                                  | 1     | 1   | services panel                            |
| S-11000     | Wall panel                                | 2     | 1   | patient services panels                   |