

**Room Name** | Patient Bay - Holding, 6m2

**Room Number:** PBTR-H-6

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	6.00
<b>Remarks</b>	
<b>Occupancy</b>	1 patient; 1 - 2 staff intermittently
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	
<b>Description or Special Requirements</b>	A Patient Bed Bay used for holding of patients prior to procedures, observation of patients following procedures or for assessment and treatment of patients with non acute conditions. The Patient Bay will have close access to a staff handwashing basin. Requirement for services including medical gases and power will be dependant on the use of the bay. Body Protected electrical area

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3092	Wall protection	MDF	Laminate	Bed protection wall panel	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	Default = set plasterboard; plasterboard drop in tile ceiling also acceptable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-12900	Wire panel - for storage-bins	1	1	optional
FF-1465	Bracket - suction bottle	2	1	required if suction outlet provided
FF-150	Air flowmeter	3	1	required if air outlet provided
FF-16250	Oxygen flowmeter	3	1	required if oxygen outlet provided
FF-21755	Storage bins	3	3	for louvred panel
FF-21950	Suction adapter	3	1	required if suction outlet provided
FF-22000	Suction bottle	3	1	required if suction outlet provided
FF-4600	Curtain track - bed screen	1	1	
FF-5000	Curtain - bed screen	3	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-3725	Bed - emergency, electric	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	spatial provision required
FE-5857	Light - procedures small, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional

Room Name | Patient Bay - Holding, 6m2

Room Number: PBTR-H-6

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6030	Special: downlights	over bed/ trolley

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9000	GPO: Single	1	2	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	2	monitor
S-9040	Body protected	1	1	
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	1	
S-6030	Special: downlights	1	1	over bed/ trolley
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	1	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	
S-11000	Wall panel	2	1	patient services panels