

**Room Name** | Patient Bay - Non Acute Treatment, 10m2

**Room Number:** PBTR-NA

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	10.00
<b>Remarks</b>	
<b>Occupancy</b>	1 patient; 1 - 2 staff intermittently
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> 24 Hours
<b>Acoustics</b>	
<b>Description or Special Requirements</b>	A Patient Bed Bay used for assessment and treatment of patients with non acute conditions. The Patient Bay will have close access to a staff handwashing basin. Body Protected electrical area

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3092	Wall protection	MDF	Laminate	Bed protection wall panel	
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL	As required, equal to 'Acrovyn'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL	As required, Equal to 'Acrovyn'
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-11200	IV track - ceiling mounted	1	1	
FF-12900	Wire panel - for storage-bins	1	1	optional
FF-1465	Bracket - suction bottle	2	1	
FF-1470	Bracket - sharps	2	2	
FF-150	Air flowmeter	3	1	to services panel
FF-16250	Oxygen flowmeter	3	1	to services panel
FF-19700	Sharps bin	3	2	
FF-19802	Shelf - laminate	1	1	
FF-21755	Storage bins	3	3	on louvred panel, if provided
FF-21950	Suction adapter	3	1	to services panel
FF-22000	Suction bottle	3	1	on bracket
FF-23950	Trolley	3	1	
FF-2650	Chair - visitor, patient	3	1	
FF-4600	Curtain track - bed screen	1	1	

Room Name | Patient Bay - Non Acute Treatment, 10m2

Room Number: PBTR-NA

AusHFG code	Description	Group	Qty	Comments
FF-5000	Curtain - bed screen	3	1	
FF-6152	Dispenser - disposable glove	2	1	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-15900	Diagnostic set - wall mounted	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional
FE-5854	Bed - ICU, electric + patient mattress	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-5857	Light - procedures small, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6030	Special: downlights	over bed/ trolley

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	3	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	3	monitor
S-9040	Body protected	1	1	
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6030	Special: downlights	1	1	over bed/ trolley
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	1	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	

Room Name | Patient Bay - Non Acute Treatment, 10m2

Room Number: PBTR-NA

AusHFG code	Description	Group	Qty	Comments
S-11000	Wall panel	2	1	patient services panels