

**Room Name** | **Plaster Room**

**Room Number: PLST**

**Last modified** | 01/03/2016  
**Briefed Area** | 14.00  
**Remarks**  
**Occupancy** | 1 patient; 2 -3 staff  
**Hours of Operation** |  24 Hours  
**Acoustics**  
**Description / Special Requirements**

*The Plaster Room allows for the application of Plaster of Paris, or other splints, and for the closed reduction of displaced fractures or dislocations under sedative or regional anaesthesia. Typically a dedicated room provided for high volume services, otherwise, a generic Treatment Room may be used with the inclusion of a plaster trap and other specific plastering equipment. Acoustics: Sound attenuation level - highAcoustic privacy is required Body Protected electrical area*

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2726	Floor finish	Vinyl, non slip		Seamless coved	Under basin. Significant change in colour to be avoided.
3000	Wall finish	Paint	Acrylic, washable		
2692	Wall protection			Bed protection wall panel	or similar
2727	Wall finish			Splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG.
2537	Wall protection			Crash rail at 900 AFFL	
5007	Ceiling - Plasterboard	Plasterboard	Paint	Bulkhead	Between above bench joinery and ceiling.
9128	Door - 1200mm	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel	1400mm clear opening, sliding cover to glazing
2529	Door protection	Composite	Prefinished PVC	To door frame	To be decided at project level.
2712	Door protection			Protection plate to 900 AFFL	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1010	Bench - stainless steel	1	1	With SS sink and wet edge. Length to suit layout, refer RLS or project specific requirements.
FF-1465	Bracket - suction bottle	2	1	
FF-1470	Bracket - sharps	2	1	
FF-150	Air flowmeter	3	1	
FF-16250	Oxygen flowmeter	3	1	
FF-17501	Trolley - plaster	3	1	

Room Name | Plaster Room

Room Number: PLST

AusHFG code	Description	Group	Qty	Comments
FF-19700	Sharps bin	3	1	
FF-22000	Suction bottle	3	1	
FF-4360	Cupboard - door ht adj. shelves	1	1	Number to suit layout, refer RLS or project specific requirements.
FF-4420	Cupboard - under bench, lockable	1	1	Number to suit layout, refer RLS or project specific requirements.
FF-4420	Cupboard - under bench, lockable (s)	1	1	Number to suit layout, refer RLS or project specific requirements.
FF-4470	Cupboard - wall mounted, lockable	1	1	Number to suit layout, refer RLS or project specific requirements.
FF-4472	Cupboard - wall mounted, lockable	1	1	
FF-6152	Dispenser - disposable glove	2	1	to basin
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-6153	Dispenser - moisturiser	2	1	to hand basin. Depends on operational policy.
FF-5830	Dispenser - antiseptic hand rub	2	1	
FF-5824	Waste bin - general	3	2	

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11400	Computer - PC & monitor	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	On bench, flatscreen, or wall mounted. If wall mounted add bracket. PACS images may be viewed, refer specific project requirements.
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	elbow action levers or handsfree optional.
FE-31700	Light - examination, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-40300	Plaster trap	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	under sink, mobile
FE-49110	Sink - 450x350x300D	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	hot water; tapware, long lever, wall mounted
FE-54520	Telephone - handset, handsfree (WM)	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Room Name | Plaster Room

Room Number: PLST

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-5622	Bed - inpatient, electric + standard patient mattress	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-40330	Saw - plaster	3	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-4045	Tapware - elbow mixer	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single		1	4 Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)		1	2 monitor
S-9001	GPO: Double		1	3
S-9015	GPO: Cleaner		1	1
S-9040	Body protected		1	1
S-1005	Voice / Data outlet: single		1	1 in ceiling for data projector; optional
S-1006	Voice / Data outlet: double		1	2 1 outlet for telephone
S-5000	Airconditioning		1	1
S-6001	General: colour corrected		1	1
S-6200	Light switches		1	2
S-2088	Light switch: single		1	1
S-6055	Special: task light, built in		1	1 under O/H cupboards
S-8000	Patient/ Staff call		1	1 + indicator button & light
S-8005	Patient call handset		1	1 call button & light switch on the handset
S-8080	Emergency call		1	1 + indicator button & light
S-1951	Staff assist call		1	1 + indicator button & light
S-10005	Duress alarm		1	1
S-2072	Scavenge Outlet		1	1 and controls, on wall, optional
S-7000	Oxygen (O2)		1	1
S-7010	Nitrous Oxide (N2O)		1	1 services panel

Room Name | Plaster Room

Room Number: PLST

AusHFG code	Description	Group	Qty	Comments
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	
S-11000	Wall panel	2	1	patient services panels