

Room Name | Preparation Room - Non Sterile (Pharmacy) **Room Number:** PREP

Last modified	01/03/2016
Briefed Area	12.00
Remarks	
Occupancy	Up to 3
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	
Description or Special Requirements	<i>The Preparation Room provides a wet area for cleaning of equipment and extemporaneous preparation and compounding of medications as required. The Preparation area should be located in close proximity to the Assembly/ Preparation area.</i>

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL	Equal to 'Acrovyn'; as required
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	2	
FF-23950	Trolley	3	2	
FF-4420	Cupboard - under bench, lockable	1	5	adjustable shelves
FF-4470	Cupboard - wall mounted, lockable	1	1	over bench, adjustable shelves
FF-6154	Dispenser - paper/ hand towel	2	2	to sink & handbasin
FF-6156	Dispenser - soap	2	2	to sink & handbasin
FF-44711	Overbench single door lockable (600hx400wx350d)	1	2	
FF-44716	Overbench double door lockable (600hx800wx350d)	1	5	
FF-5824	Waste bin - general	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-B (sim)
FE-48100	Sink & drainer - R bowl, 930mmL	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	hot water
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to bench, optional

Room Name | Preparation Room - Non Sterile (Pharmacy)

Room Number: PREP

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-40403	Tapware - accessible basin mixer	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6055	Special: task light, built in	under O/H cupboards

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double		3	
S-1006	Voice / Data outlet: double		1	1 outlet for telephone
S-5000	Airconditioning		1	
S-6000	General fluorescent		1	
S-6200	Light switches		3	
S-6055	Special: task light, built in		1	under O/H cupboards