

Room Name | Procedure Room, 20m2

Room Number: PROC-20

Last modified	01/03/2016
Briefed Area	20.00
Remarks	
Occupancy	1 patient; 2-4 staff
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	Sound attenuation level medium, Acoustic privacy is required.
Description / Special Requirements	<i>The Procedure Room may be required for the performance of procedures that do not require the full facilities of the Operating Suite. This may include suturing or wounds, dressings, administration of local anaesthesia and use of medical gases in connection with the procedures being performed. General anaesthesia will not be administered in this room. Acoustics: Sound attenuation level - High. Acoustic privacy is required. Body Protected electrical area Additional Design Considerations:- Lead shielding may be required depending on use of mobile Imaging equipment- Treatment of bariatric patients including mobile, bariatric lifter access.</i>

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved	Under basin. Significant change in colour to be avoided.
3000	Wall finish	Paint	Acrylic, washable		
2692	Wall protection			Bed protection wall panel	or similar
2727	Wall finish			Splashback	Selection of material to comply with Part D Infection Prevention and Control AusHFG.
5007	Ceiling - Plasterboard	Plasterboard	Paint	Bulkhead	Between above bench joinery and ceiling.
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
8040	Door protection	Composite	Prefinished PVC	To door frame	Optional. To be decided at project level.
9128	Door - 1200mm	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel	1500mm clear opening, cover to glazing
6021	Cornice	Tape set	Paint	Set between plasterboard wall and ceiling	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate		1	Optional . Length to suit layout, refer RLS or project specific requirements.
FF-1465	Bracket - suction bottle		2	
FF-1470	Bracket - sharps		1	
FF-150	Air flowmeter		1	
FF-15100	Bracket - monitor		1	

Room Name | Procedure Room, 20m2

Room Number: PROC-20

AusHFG code	Description	Group	Qty	Comments
FF-16250	Oxygen flowmeter	3	2	
FF-19700	Sharps bin	3	1	wall mounted
FF-21700	Stool - adjustable, mobile, high	3	1	
FF-21950	Suction adapter	3	2	
FF-22000	Suction bottle	3	2	
FF-4360	Cupboard - door ht adj. shelves	1	1	Optional, lockable. Number to suit layout.
FF-4420	Cupboard - under bench, lockable	1	2	adjustable shelf, optional. Number to suit layout, refer RLS or project specific requirements. Storage solution for consumables and equipment to meet project specific Infection Control and WH&S requirements.
FF-4470	Cupboard - wall mounted, lockable	1	2	over bench, adjustable shelf, optional. Number to suit layout, refer RLS or project specific requirements. Storage solution for consumables and equipment to meet project specific Infection Control and WH&S requirements.
FF-4600	Curtain track - bed screen	1	1	to door opening
FF-5000	Curtain - bed screen	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-6214	Trolley - equipment	3	1	
FF-6153	Dispenser - moisturiser	2	1	Optional. Depends on Operational Policy.
FF-5830	Dispenser - antiseptic hand rub	2	1	
FF-5824	Waste bin - general	3	1	
FF-5550	Blind - integral	1	1	Optional, to external windows. Number to suit window configuration.

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11400	Computer - PC & monitor	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	On bench or wall mounted, optional. If wall mounted add bracket. PACS images may be viewed, refer

Room Name | Procedure Room, 20m2

Room Number: PROC-20

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
												specific project requirements.
FE-3100	Basin - scrub, Type A	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	elbow action levers or handsfree optional.
FE-36055	Monitor - cardiac with vital signs	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional
FE-54520	Telephone - handset, handsfree	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to bench or wall mounted
FE-9700	Clock - analogue, electric	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-5622	Bed - inpatient, electric + standard patient mattress	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-5857	Light - procedures small, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single		1	3 Bedhead low level, for electric bed
S-9000	GPO: Single		1	1 Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)		1	4 monitor
S-9001	GPO: Double		1	3
S-9040	Body protected		1	1
S-1006	Voice / Data outlet: double		1	2 1 outlet for telephone
S-1120	Monitor connection facilities and cabling		1	0 optional
S-5000	Airconditioning		1	1
S-6001	General: colour corrected		1	1
S-6200	Light switches		1	2
S-8000	Patient/ Staff call		1	1 + indicator button & light
S-8005	Patient call handset		1	1 call button & light switch on the handset
S-8080	Emergency call		1	1 + indicator button & light
S-1951	Staff assist call		1	1 + indicator button & light

Room Name | Procedure Room, 20m2

Room Number: PROC-20

AusHFG code	Description	Group	Qty	Comments
S-10005	Duress alarm	1	1	
S-7000	Oxygen (O2)	1	2	
S-7010	Nitrous Oxide (N2O)	1	1	services panel
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	2	
S-7070	Scavenge	1	1	services panel
S-11000	Wall panel	2	1	patient services panels