

**Room Name** | Screening Room (Fluoroscopy)

**Room Number:** SCRNR

**Last modified** | 01/03/2016  
**Briefed Area** | 36.00  
**Remarks**  
**Occupancy** | 1 patient; 1 - 2 staff  
**Hours of Operation** |  Available 24 Hours  
**Acoustics**  
**Description / Special Requirements**

*Screening Room (Fluoroscopy) is a room for undertaking radiographic procedures involving contrast media. Patient Change, Toilets and Shower should be located in close proximity. The room may include a preparation area with sink. Additional Design Requirements: - Radiation shielding to walls and glazing as advised by Radiation Consultant - Unistrut type ceiling may be required, depending on equipment to be installed - Cable ducting between the X-ray table, vertical bucky and control area may be required, depending on equipment type and layout - 'X-ray in Use' warning lights will be required outside each entry door Body Protected electrical area*

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin & sink, tiles also acceptable
5030	Ceiling - Plasterboard	Plasterboard	Prefinished	Drop-in tiles, 600x1200	at 3000 mm AFFL
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9001	Door - 1100mm	Solid Core	Paint	Single leaf	to Patient Change/ Toilet
9130	Door - 1600mm	Solid Core	Paint	1 1/2 leaf, with lead shielding	Patient entry/exit 1400mm clear opening
7025	Observation	Lead glass	Clear	Internal window	to control booth
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1010	Bench - stainless steel	1	1	with wet edge
FF-1090	Bench - laminate, free standing	1	1	workstation
FF-11460	Keyboard shelf - slide out	1	1	for PACS computer screen
FF-11905	Rack - lead apron	1	1	
FF-1480	Bracket - ECG monitor	3	1	
FF-150	Air flowmeter	3	1	to services panel
FF-16250	Oxygen flowmeter	3	1	to services panel
FF-1650	Chair - client	3	1	
FF-21950	Suction adapter	3	1	
FF-22000	Suction bottle	3	1	

Room Name | Screening Room (Fluoroscopy)

Room Number: SCRN

AusHFG code	Description	Group	Qty	Comments
FF-4410	Cupboard - under bench	1	1	adjustable shelf
FF-4420	Cupboard - under bench, lockable	1	2	
FF-4470	Cupboard - wall mounted, lockable	1	2	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-5824	Waste bin - general	3	1	to basin

### Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11415	Computer - PACS	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	flat screen
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-B (sim)
FE-47800	Sink, SS - single in bench	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	warm water
FE-54520	Telephone - handset, handsfree	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-61600	IMG - bucky, chest	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-62400	IMG - control booth	1	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	with lead glazing
FE-66000	IMG - X-ray table, floating top	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-67000	IMG - Screening (Fluoroscopy) imaging unit	1	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-4045	TAPWARE - ELBOW MIXER: TAP MIXER, LONG LEVER		1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-62152	IMG - console, control (integrated stand)	1	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-68400	IMG: generator	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

### Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6110	Downlights: dimmable	optional
S-12030	Lead lining	to walls and doors as specified

Room Name | Screening Room (Fluoroscopy)

Room Number: SCR N

## Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	2	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	2	monitor
S-9001	GPO: Double	1	5	
S-9030	Cardiac protected	1	1	
S-9040	Body protected	1	1	
S-9060	GPO: Special: for equipment	1	2	TV, ceiling
S-1006	Voice / Data outlet: double	1	3	1 outlet for telephone
S-1040	Intercom	1	1	optional
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	5	
S-6110	Downlights: dimmable	1	1	optional
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	1	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	
S-11000	Wall panel	2	1	patient services panels
S-12030	Lead lining	1	1	to walls and doors as specified