

Room Name | Specimen Collection Bay, 9m2

Room Number: SPECC

Last modified	01/03/2016
Briefed Area	9.00
Remarks	
Occupancy	1 patient; 1 staff member
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	
Description or Special Requirements	A Patient Bay used for collection of specimens from patients. The Specimen Collection Bay will have close access to a staff handwashing basin. Body Protected electrical area

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL	Equal to 'Acrovy'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL	Equal to 'Acrovyn'
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	plasterboard drop in tile ceiling also acceptable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1110	Bench - laminate, writing	1	1	small, 900mm high
FF-12900	Wire panel - for storage-bins	1	1	
FF-1470	Bracket - sharps	2	1	on trolley
FF-19700	Sharps bin	3	1	on trolley
FF-21680	Stool - adjustable, mobile	3	1	staff use
FF-21755	Storage bins	3	1	for louvred panel
FF-2200	Chair - recliner	3	1	or mobile trolley/ bed
FF-4600	Curtain track - bed screen	1	1	
FF-5000	Curtain - bed screen	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-7402	Trolley - equipment	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-5857	Light - procedures small, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

Room Name | Specimen Collection Bay, 9m2

Room Number: SPECC

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6030	Special: downlights	over bed/ trolley

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	1	monitor
S-9015	GPO: Cleaner	1	1	
S-9040	Body protected	1	1	
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6030	Special: downlights	1	1	over bed/ trolley