

Room Name	Store - Accountable Drugs	Room Number: STAD
Last modified	01/03/2016	
Briefed Area	5.00	
Remarks		
Occupancy	1 - 2 intermittently	
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours	
Acoustics		
Description or Special Requirements	<p>The Store - Accountable Drugs is a strongroom for storage of accountable (Schedule 8) drugs and medications, located within the Pharmacy Unit. Refrigerated storage may also be required. The strongroom will require adequate ventilation and a gate door for security when the main door is open. Accountable drugs storage facilities are to comply with NSW Health Pharmaceuticals Services Branch Policy and the requirements noted in the NSW Police Service document - 'Minimising the Risks'. Additional Design Considerations: - The strongroom should be independent of the rest of the building structure with no beams or columns passing through the ceiling, walls or floor - The ceiling, walls and floor should be constructed of concrete with a compressive strength of 70 m/p/a with either 1 cm thick tang bar or 1 cm thick reinforcing rods in three levels in a criss cross pattern. The ceiling, walls and floor should be a minimum thickness of 300mm. - The door should be torch and drill resistant, fitted with a combination lock facility incorporating duress features and an internal release mechanism in case persons are trapped within - A torch and drill resistant breather tube must be fitted, to comply with Fire Regulations - Security detection equipment should be incorporated into the alarm system, to detect any attack on the structure - A telephone should be installed for staff safety; the telephone should be concealed to restrict unauthorised tampering</p>	

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
9030	Door - 910mm	Steel	Paint	Strongroom, security door	Equal to 'Chubb' Pacific 100
9032	Doors	Steel	Paint	Strongroom, grille gate door	inner door
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	
FF-19968	Shelving - pharmacy stock flow	3	2	
FF-21760	Storage unit - under bench	1	1	drawer/ cupboard unit
FF-5597	Shelving unit - over bench, adjustable	1	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-44350	Refrigerator - drugs	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	under bench
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	on bench, optional

Service Requirements

Room Name | Store - Accountable Drugs

Room Number: STAD

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-5015	Ventilation	
S-6000	General fluorescent	
S-6055	Special: task light, built in	under O/H cupboards

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9001	GPO: Double	1	2	
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-5015	Ventilation	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	2	
S-6055	Special: task light, built in	1	1	under O/H cupboards
S-10005	Duress alarm	1	1	
S-10010	Reed switch / alarm	1	1	to door and structure