

**Room Name** | **Stress Testing**

**Room Number: STRT**

<b>Last modified</b>	01/03/2016
<b>Briefed Area</b>	12.00
<b>Remarks</b>	
<b>Occupancy</b>	1 patient; 1 - 2 staff
<b>Hours of Operation</b>	<input checked="" type="checkbox"/> Available 24 Hours
<b>Acoustics</b>	Acoustic privacy is required
<b>Description or Special Requirements</b>	Room for undertaking patient diagnostic stress testing procedures. The Stress Testing room should be located close to patient toilet and change rooms. Acoustics: Acoustic privacy required Body Protected electrical area

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin; tiles also acceptable
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9004	Door - 1100mm	Solid Core/ Glass	Paint	Single leaf, observation panel	910mm clear opening
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1650	Chair - client	3	1	
FF-2100	Chair - ergonomic, office	3	1	
FF-22615	Table - computer	3	1	
FF-3350	Clock - battery operated	3	1	
FF-3400	Coathook	1	1	
FF-4700	Curtain track - privacy screen (90 deg)	1	1	to entry door
FF-5250	Curtain - privacy screen	3	1	to entry door
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-7520	Exercise bicycle	3	1	
FF-5824	Waste bin - general	3	1	

Room Name | Stress Testing

Room Number: STRT

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11400	Computer - PC & monitor	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-B (sim)
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to computer table
FE-56600	Treadmill - automatic	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	

## Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double		4	
S-9015	GPO: Cleaner		1	
S-9040	Body protected		1	
S-1006	Voice / Data outlet: double		1	1 outlet for telephone
S-5000	Airconditioning		1	
S-6001	General: colour corrected		1	
S-6200	Light switches		1	
S-8000	Patient/ Staff call		2	+ indicator button & light
S-8005	Patient call handset		2	call button & light switch on the handset
S-8010	Staff/ Nurse assist call		1	+ indicator button & light
S-8080	Emergency call		1	+ indicator button & light
S-1951	Staff assist call		1	+ indicator button & light